



PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT
 Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 19151

1. OWNER Johnson ADDRESS AT WELL LOCATION 2261 E Dandelion St
 MAILING ADDRESS 2261 E Dandelion St
Pahrump
 2. LOCATION NE 1/4 NW 1/4 Sec. 36 T. 20 N. R. 53 E. Nye County
 PERMIT NO. 41-011-11 Calorado Valley Unit 2
 Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other

6. LITHOLOGIC LOG

| Material | Water Strata | From | To | Thick-ness |
|------------------|--------------|------|------|------------|
| 311 | | 0 | 20' | 20' |
| White Clay | | 20' | 45' | 15' |
| caliche | | 45' | 50' | 5' |
| white clay | | 50' | 75' | 25' |
| caliche | | 75' | 80' | 5' |
| white clay | | 80' | 100' | 20' |
| caliche | | 100' | 105' | 5' |
| brown clay | | 105' | 125' | 20' |
| granular caliche | | 125' | 140' | 15' |
| brown clay | | 140' | 155' | 15' |
| caliche | | 155' | 160' | 5' |

DCNR/DWR
 RECEIVED
 FEB 04 2002
 LAS VEGAS OFFICE

8. WELL CONSTRUCTION
 Depth Drilled 160 Feet Depth Cased 160 Feet
 HOLE DIAMETER (BIT SIZE)
 From 12 Inches To 0 Feet 160 Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

| Size O.D. (Inches) | Weight/Ft. (Pounds) | Wall Thickness (Inches) | From (Feet) | To (Feet) |
|--------------------|---------------------|-------------------------|-------------|-----------|
| 6.625 | 7.33 | .316 | 0 | 160 |

Perforations:
 Type perforation saw cut
 Size perforation 1/8" x 3"
 From 120 feet to 160 feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Depth of Seal 50' Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout
 Gravel Packed: Yes No
 From 50 feet to 160 feet

9. WATER LEVEL
 Static water level 70 feet below land surface
 Artesian flow _____ G.P.M. P.S.I.
 Water temperature _____ °F Quality _____

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Lake Co. Co.
 Address 4191 S. Packie St
Pahrump NV 89048
 Nevada contractor's license number issued by the State Contractor's Board 0049225
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2116
 Signed Forest LaRue
 By driller performing actual drilling on site or contractor
 Date Dec 2, 2001

Date started Nov 20 2001
 Date completed Nov 27 2001

7. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift

| G.P.M. | Draw Down (Feet Below Static) | Time (Hours) |
|--------|-------------------------------|--------------|
| | | |
| | | |
| | | |
| | | |