

STATE OF NEVADA
 DIVISION OF WATER RESOURCES

OFFICE USE ONLY
 Log No. 85518
 Permit No. _____
 Basin 210
 NOTICE OF INTENT NO. 18458

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT
 Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

1. OWNER Joseph A. Martinetti
 MAILING ADDRESS P.O. Box 3933
Huntington Beach, CA 92605
 ADDRESS AT WELL LOCATION Kyle canyon RD
8530 ROBERTSON RD

2. LOCATION SE 1/4 NW 1/4 Sec. 9 T 19S N/S R 59E E Clark County
 PERMIT NO. na 126-09-692-009 na
Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____
 PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
loose dirt and rock		0	8	8
sand and gravel		8	200	192
cemented sand and gravel		200	300	100
sandy clay and gravel		300	500	200
cemented sand and gravel		500	580	80
sandy clay and gravel with layers of cemented sand and gravel	x	580	770	190
red shale		770	800	30
well produces very little water				

8. WELL CONSTRUCTION
 Depth Drilled 800 Feet Depth Cased 800 Feet
 HOLE DIAMETER (BIT SIZE)
 From 10 Inches To 800 Feet
 From _____ Inches To _____ Feet
 From _____ Inches To _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6.625	3.63	.280	0	800

Perforations:
 Type perforation saw
 Size perforation 1/8 by 3 inch
 From 560 feet to 800 feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Depth of Seal 60 Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout
 Gravel Packed: Yes No
 From 60 feet to 800 feet

DCNR/DWR
 RECEIVED
 FEB 04 2002
 LAS VEGAS OFFICE

Date started 12/17/2001, 19____
 Date completed 1/18/2002, 19____

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailor <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift			

9. WATER LEVEL
 Static water level 580 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature _____ °F Quality _____

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name GREAT BASIN DRILLING CO. OF NEVADA, INC.
 Address P.O. BOX 4220
PAHRUMP, NV. 89048
 Nevada contractor's license number issued by the State Contractor's Board 47333
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1426
 Signed [Signature]
 by driller performing actual drilling on-site or contractor
 Date 1/23/02