WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 85528
Permit No.
Basin 162

NOTICE OF INTENT NO. 20227

1. OWNER John Parro
MAILING ADDRESS 2279 So Fork Rd.
Cody WY

ADDRESS AT WELL LOCATION
9661 So. Parko CT
Pahrump NV

2. LOCATION NW ¼ SE ¼ Sec. 36 T. 21S N/S R. 53 E. Nye County
PERMIT NO. 44-481-15 (Issued by Water Resources) | 44-481-15 (Parcel No.) | NONE (Subdivision Name)

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☒ Cable ☐ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Surface		0	6	6
Broken Caticle		6	9	3
Hard Limestone		9	14	5
Clay w/strip of Hard Limestone		14	138	124
Broken Soft Shale	X	138	146	8
Brown clay	X	146	168	22
Cemented gravel		168	180	12

DCNR/DWR
RECEIVED
FEB 0 2 2002
LAS VEGAS OFFICE

Date started 1-13-2002, 19
Date completed 1-15-2002, 19

7. WELL TEST DATA
TEST METHOD: ☒ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
20	20	15 min

8. WELL CONSTRUCTION
Depth Drilled 180 Feet Depth Cased 180 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
12 Inches		0 Feet	180 Feet
Inches		Feet	Feet
Inches		Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
8	17#	.188	0	180

Perforations:
Type perforation Torch cut
Size perforation 8" Long x 3/8" wide
From 140 feet to 180 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 50
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☒ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 50 feet to 180 feet

9. WATER LEVEL
Static water level 79 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Charles Nyberg Well Drilling (Contractor)
Address 1060 W Basin Rd (Contractor)
Pahrump NV 89060
Nevada contractor's license number issued by the State Contractor's Board 7484
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 725
Signed Charles Nyberg (CDR) (By driller performing actual drilling on site or contractor)
Date 1-21-2002

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627