

STATE OF NEVADA
 DIVISION OF WATER RESOURCES

OFFICE USE ONLY
 Log No. 85533
 Permit No. _____
 Basin 162
 NOTICE OF INTENT NO. 22331

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

1. OWNER Red Rock Builders ADDRESS AT WELL LOCATION _____
 MAILING ADDRESS 5420 N. Blagg 5420 N. Blagg
Pahrump, NV 89048
 2. LOCATION SE 1/4 SE 1/4 Sec. 16 T 19S N/S R 53E E Nye County
 PERMIT NO. 29-262-15 Country Place II
 Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
<u>brown silt</u>		<u>0</u>	<u>12</u>	<u>12</u>
<u>brown loam with gravel</u>		<u>12</u>	<u>22</u>	<u>10</u>
<u>See next line</u>		<u>22</u>	<u>43</u>	<u>21</u>
<u>brown loam with caleche strings</u>				
<u>brown loam with gravel</u>		<u>43</u>	<u>50</u>	<u>7</u>
<u>brown loam</u>		<u>50</u>	<u>96</u>	<u>46</u>
<u>brown clay</u>		<u>96</u>	<u>114</u>	<u>18</u>
<u>brown loam</u>		<u>114</u>	<u>132</u>	<u>18</u>
<u>brown loam with gravel</u>	<u>x</u>	<u>132</u>	<u>200</u>	<u>68</u>

DCNR/DWR
RECEIVED
JAN 04 2002
LAS VEGAS OFFICE

8. WELL CONSTRUCTION
 Depth Drilled 200 Feet Depth Cased 200+1 Feet
 HOLE DIAMETER (BIT SIZE)
 From To
11 Inches 0 Feet 200 Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet
 CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 5/8</u>	<u>3.7</u>	<u>.280</u>	<u>0</u>	<u>200</u>

Perforations:
 Type perforation sawcut
 Size perforation .188
 From 180 feet to 200 feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet
 From _____ feet to 0 feet
 From _____ feet to _____ feet
 Surface Seal: Yes No Seal Type:
 Depth of Seal 50 Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout
 Gravel Packed: Yes No
 From 50 feet to 200 feet

Date started 11/3/01, 19____
 Date completed 11/3/01, 19____

7. WELL TEST DATA

TEST METHOD:	<input type="checkbox"/> Bailer	<input type="checkbox"/> Pump	<input type="checkbox"/> Air Lift
G.P.M.	Draw Down (Feet Below Static)	Time (Hours)	

9. WATER LEVEL
 Static water level 120 feet below land surface
 Artesian flow _____ G.P.M. P.S.I.
 Water temperature cool °F Quality good

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Strickland Construction Co., Inc. Contractor
 Address 5801 S. Homestead Contractor
Pahrump, NV 89048
 Nevada contractor's license number issued by the State Contractor's Board 40277
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2086
 Signed [Signature]
 By driller performing actual drilling on-site or contractor
 Date 12-26-01