

STATE OF NEVADA
 DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
 Log No. 85536
 Permit No. _____
 Basin 162

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 22334

1. OWNER Raymond Diaz ADDRESS AT WELL LOCATION _____
 MAILING ADDRESS 1861 Keith 1861 Keith
Pahrump, NV 89048

2. LOCATION NW 1/4 NE 1/4 Sec. 35 T 21S N/S R 53E E Nye County
 PERMIT NO. 41-333-08 Calvada Valley
 Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED 4. PROPOSED USE 5. WELL TYPE

New Well Replace Recondition Domestic Irrigation Test Cable Rotary RVC
 Deepen Abandon Other Municipal/Industrial Monitor Stock Air Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
brown loam		0	16	16
grey caleche with gravel		16	21	5
grey clay		21	26	5
brown loam		26	42	16
See next line	x	42	91	49
brown loam with caleche strings				
brown caleche	x	91	98	7
brown loam with rock	x	98	112	14
rock	x	112	170	58

DCNR/DWR
RECEIVED
JAN 04 2002
LAS VEGAS OFFICE

8. WELL CONSTRUCTION

Depth Drilled 170 Feet Depth Cased 166+1 Feet

HOLE DIAMETER (BIT SIZE)

Inches	From	Feet	To	Feet
<u>11</u>		<u>0</u>		<u>170</u>

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 5/8</u>	<u>3.7</u>	<u>.280</u>	<u>0</u>	<u>166</u>

Perforations:

Type perforation sawcut
 Size perforation .188

From 140 feet to 166 feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Depth of Seal 50 Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout

Gravel Packed: Yes No
 From 50 feet to 166 feet

9. WATER LEVEL

Static water level 75 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature cool °F Quality good

10. DRILLER'S CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Strickland Construction Co., Inc.
 Contractor

Address 5801 S. Homestead
 Contractor

Pahrump, NV 89048

Nevada contractor's license number issued by the State Contractor's Board 40277

Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2086

Signed [Signature]
 By driller performing actual drilling on-site or contractor

Date 11-22-01

Date started 10/16/01 19__
 Date completed 10/16/01 19__

7. WELL TEST DATA

TEST METHOD:	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift		
G.P.M.		