

OFFICE USE ONLY
 Log No. 85540
 Permit No. 49608
 Basin. 21B

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT
 Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 22354

1. OWNER Nevada Power ADDRESS AT WELL LOCATION 1933 H16B
 MAILING ADDRESS 6226 West Sahara Ave. 3 mi East
Las Vegas, Nevada 89146
 2. LOCATION NE 1/4 NE 1/4 Sec. 26 T. 13 N. R. 63 E. Clark County
 PERMIT NO. 49608 Issued by Water Resources Parcel No. Coyote Spring Valley Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
slay overburden		0	275'	275'
Limestone		275'	595'	320'
clay		595'	610'	15'
Limestone		610'	720'	110'
DONNADINI RECEIVED FEB 2 1902 LAS VEGAS OFFICE				

8. WELL CONSTRUCTION
 Depth Drilled 711 Feet Depth Cased 710 Feet
 HOLE DIAMETER (BIT SIZE)
 From 36 Inches 0 Feet 50 Feet
22 Inches 50 Feet 720 Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>24"</u>	<u>94.62</u>	<u>.375</u>	<u>0</u>	<u>50</u>
<u>16"</u>	<u>62.56</u>	<u>.375</u>	<u>0</u>	<u>460</u>
<u>16"</u>	<u>62.56</u>	<u>.375</u>	<u>700</u>	<u>710</u>

Perforations:
 Type perforation S.S. 304 Wire wrapped
 Size perforation 100 Slot size
 From 460 feet to 700 feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Neat Cement
 Cement Grout
 Concrete Grout
 Depth of Seal 50'
 Placement Method: Pumped Poured
 Gravel Packed: Yes No
 From 0 feet to 711 feet

9. WATER LEVEL
 Static water level 380' feet below land surface
 Artesian flow NO G.P.M. _____ P.S.I.
 Water temperature 144 WARM Quality NA

Date started 2-4-02 1902
 Date completed 2-25-02 1902

7. WELL TEST DATA

TEST METHOD:	TEST METHOD:		
	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift	<u>at 100 psi</u>	<u>150'</u>	<u>NA</u>
			<u>48</u>

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Wayne G. Stoen Contractor
 Address 12030 E Riggs Road
Chandler, Arizona 85245
 Nevada contractor's license number issued by the State Contractor's Board 19101
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1887
 Signed Lowell Stephen Clever
 By driller performing actual drilling on site or contractor
 Date 2-25-02