WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

# WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 85566
Permit No.
Basin 272

NOTICE OF INTENT NO. 23159

1. OWNER James Trotter / Tosco MKT
MAILING ADDRESS 1500 N Priest Dr
Tempe Az 85281

ADDRESS AT WELL LOCATION 2300 S Las Vegas Blvd
Las Vegas, Nevada

2. LOCATION SE ¼ SE ¼ Sec. 4 T 21 N/S R 61 E Clark County

PERMIT NO. Issued by Water Resources | Parcel No. 16204813072 | Subdivision Name

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☒ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☐ Air ☒ Other Hollow Stem

6. LITHOLOGIC LOG

| Material | Water Strata | From | To | Thickness |
|---|---|---|---|---|
| Backfill | | 0 | 2 | 2 |
| Silts | | 2 | 7 | 5 |
| caliche | | 7 | 8 | 1 |
| Clays | | 8 | 12 | 4 |
| clays w/ caliche | | 12 | 28 | 16 |

RECEIVED
01 DEC 31 AM 11:01
STATE ENGINEERS OFFICE

Date started 18 Dec 2001, 19—
Date completed 18 Dec 2001, 19—

7. WELL TEST DATA

TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

| | G.P.M. | Draw Down (Feet Below Static) | Time (Hours) |
|---|---|---|---|
| | | | |

8. WELL CONSTRUCTION
Depth Drilled 28 Feet Depth Cased 28 Feet

HOLE DIAMETER (BIT SIZE)

| | From | To |
|---|---|---|
| 8 Inches | 0 Feet | 28 Feet |
| Inches | Feet | Feet |
| Inches | Feet | Feet |

CASING SCHEDULE

| Size O.D. (Inches) | Weight/Ft. (Pounds) | Wall Thickness (Inches) | From (Feet) | To (Feet) |
|---|---|---|---|---|
| 2 | | 040 | 0 | 25 |

Perforations:
Type perforation SLOTTED
Size perforation 020
From 25 feet to 27.50 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 21
Placement Method: ☐ Pumped ☒ Poured

Seal Type:
☒ Neat Cement
☐ Cement Grout
☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 23 feet to 28 feet

9. WATER LEVEL
Static water level feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name THF Drilling
Contractor
Address 2420 S. 16th ave
Contractor
Phoenix Az 85005

Nevada contractor's license number issued by the State Contractor's Board 0045849

Nevada driller's license number issued by the Division of Water Resources, the on site driller M-2183

Signed [signature]
By driller performing actual drilling on site or contractor

Date 18 Dec 2001

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627