

STATE OF NEVADA
 DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
 Log No. 85584
 Permit No. _____
 Basin 162

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 22852

1. OWNER **CORDERO**
 MAILING ADDRESS 1210 N ROCKAFELLER
PAHRUMP, NV 89048

ADDRESS AT WELL LOCATION 1210 N ROCKAFELLER

2. LOCATION SW 1/4 SW 1/4 Sec. 2 T 20S
 PERMIT NO. _____
 Issued by Water Resources _____ Parcel No. 35-033-54

N/S R 53E E _____ NYE County
 Subdivision Name _____

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
CLAY & GRAVEL		0	96	96
CALICHIE	WB	96	102	6
CLAY		102	128	26
CALICHIE	WB	128	134	6
CLAY		134	147	13
CALICHIE	WB	147	153	6
CLAY		153	167	14
CALICHIE	WB	167	171	4
CLAY		171	180	9

8. WELL CONSTRUCTION

Depth Drilled 180 Feet Depth Cased 180 Feet

HOLE DIAMETER (BIT SIZE)
 From 10.25 Inches To 0 Feet 180 Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6.625</u>	<u>3.63</u>	<u>.280</u>	<u>0</u>	<u>180</u>

Perforations:

Type perforation SAW CUT
 Size perforation 1/8 X 3
 From 120 feet to 140 feet
 From 160 feet to 180 feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Depth of Seal 50 _____
 Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout
 Gravel Packed: Yes No
 From 50 feet to 180 feet

9. WATER LEVEL

Static water level 56 feet below land surface
 Artesian flow _____ G.P.M.
 Water temperature _____ "F" Quality _____

10. DRILLER'S CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.

Name GREAT BASIN DRILLING CO. OF NEVADA, INC.
 Contractor

Address P.O. BOX 4220
 Contractor

PAHRUMP, NV. 89048

Nevada contractor's license number issued by the State Contractor's Board 47333


Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1642

Signed [Signature]
 By driller performing actual drilling on-site or contractor

Date 12/20/01

7. WELL TEST DATA

TEST METHOD:	Bailer	Pump	Air Lift
G.P.M.	Draw Down (Feet Below Static)	Time (Hours)	



Date started 12/10/2001, 19
 Date completed 12/11/2001, 19