WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 85601
Permit No.
Basin 212

NOTICE OF INTENT NO. 22007

1. OWNER CLARK COUNTY SCHOOL DISTRICT
MAILING ADDRESS 4212 S. PEARL ST.
LAS VEGAS NV 89121

ADDRESS AT WELL LOCATION ELM. SCHOOL 4445
SEC OGDEN & BRUCIA ST.
LAS VEGAS, NV

2. LOCATION NW ¼ SE ¼ Sec 35 T. 20 N/S R. 61 E. CLARK County

PERMIT NO. | Issued by Water Resources | Parcel No. | Subdivision Name

3. WORK PERFORMED
☑ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☑ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☑ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
SILT WITH GRAVEL		0	2	2
SILT WITH CLAY		2	3	1
CLAY WITH SILT		3	6	3
CLAY WITH GRAVEL		6	7	1
CLAY WITH SILT		7	23	16

Date started ....., 19....
Date completed ....., 19....

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 23 Feet Depth Cased 23 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
5 1/2 Inches	0 Feet	23 Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
2.375		0.308	0	23

Perforations:
Type perforation FACTORY SLOT PVC
Size perforation 0.020
From 8 feet to 23 feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet

Surface Seal: ☑ Yes ☐ No
Depth of Seal 6
Placement Method: ☐ Pumped ☑ Poured
Seal Type: ☑ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☑ Yes ☐ No
From 6 feet to 23 feet

9. WATER LEVEL
Static water level N/D' feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name CONVERSE CONSULTANTS (Contractor)
Address 731 PILOT ROAD STE H (Contractor)
LAS VEGAS, NV 89119
Nevada contractor's license number issued by the State Contractor's Board 48947
Nevada driller's license number issued by the Division of Water Resources, the on-site driller ~~M-1869~~ M-1589
Signed (By driller performing actual drilling on site or contractor)
Date 4/10/02

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627