

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 23357

1. OWNER NEVADA POWER COMPANY ADDRESS AT WELL LOCATION RED GARDNER
 MAILING ADDRESS 6226 W. SARADA AVE POWER STATION, MOAPA, NV.
LAS VEGAS, NV

2. LOCATION NE 1/4 NE 1/4 Sec. 7 T. 15 N. R. 66 E. CLARK County _____
 PERMIT NO. 042-07-002 Issued by Water Resources Parcel No. _____ Subdivision Name _____

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE CMW-3
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
PAD FILL		0	1	1
SILTY CLAYSTONE				
W/TH CALCITE		1	5	4
SANDSTONE		5	12	7
CONGLOMERATE		12	16	4
SILTY CLAYSTONE		16	20	4
CONGLOMERATE W/TH SANDSTONE		20	30	10
SILTY CLAY		30	40	10
CLAYEY SANDSTONE		40	57	17
SILTY CLAYSTONE		57	63	6
SILTY CLAYSTONE				
WITH SANDY LENSSES		63	70	7
CLAYEY SANDSTONE		70	80	10
SILTY CLAYSTONE		80	112	32

8. WELL CONSTRUCTION
 Depth Drilled 112 Feet Depth Cased 103 Feet

HOLE DIAMETER (BIT SIZE)
 From 0 To 112
0 Inches 0 Feet 112 Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>4</u>		<u>SCA 40</u>	<u>0</u>	<u>103</u>
<u>4</u>			<u>103</u>	<u>103</u>

Perforations:
 Type perforation FAZZOBY SLOT PVC
 Size perforation 0.020 INCH

From 73 feet to 103 feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Neat Cement
 Cement Grout
 Concrete Grout

Depth of Seal 70

Placement Method: Pumped Poured

Gravel Packed: Yes No
 From 70 feet to 112 feet

9. WATER LEVEL
 Static water level 90.1 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature _____ °F Quality _____

Date started 1/31/02
 Date completed 2/1/02

7. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.


Name CONVERSE CONSULTANTS Contractor
 Address 731 PILOT ROAD, STE H Contractor
LAS VEGAS, NV 89115

Nevada contractor's license number 48947
 issued by the State Contractor's Board.

Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1944

Signed Thomas W. Beall
 By driller performing actual drilling on site or contractor

Date 2/22/02



WELL LOCATION, RED GARDNER POWER PLANT,
 NEAR MOAPA, NEVADA

NOTICE OF INTENT # 23357

MOAPA
 NEVADA
 LAS VEGAS