WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 85626
Permit No. 26329
Basin 220

NOTICE OF INTENT NO. 13815

1. OWNER Bryant Robison
MAILING ADDRESS PO Box 70 Logandale NV 89021
ADDRESS AT WELL LOCATION 2885 North Moapa Valley Blvd Logandale

2. LOCATION N/E ¼ N/E ¼ Sec. 34 T. 15 N/S R. 67 E. Clark County
PERMIT NO. 26329 (Issued by Water Resources) 041-34-501-023 (Parcel No.) — (Subdivision Name)

3. WORK PERFORMED OLD Well
☐ New Well ☐ Replace ☒ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☒ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
fine Sand		65	80	15
Sand grad- Boulders		80	110	30
Clay		110	117	7
Cemented grad- Boulders		117	135	18

A twenty four inch long cement plug was placed on bottom of Casing before installation

Original well log showed 150' Total Depth. I do not believe this 16" well was originally over 110' as drilling was difficult with hard Rock and 30% Lost Circulation

Date started 11-27-01, 19
Date completed 11-28-01, 19

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☒ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
250	81	2

8. WELL CONSTRUCTION
Depth Drilled 135 Feet Depth Cased 135 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
14 3/4 Inches	0 Feet	135 Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
12		.250	0	135

Perforations:
Type perforation Factory
Size perforation 1/8 x 6"
From 93 feet to 133 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☐ Yes ☒ No
Depth of Seal
Placement Method: ☐ Pumped ☐ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 0 feet to 135 feet

9. WATER LEVEL
Static water level 11 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature warm °F Quality poor

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Davis Drilling and Pumps (Contractor)
Address HC 61 Box 54 Hiko NV 89017 (Contractor)
Nevada contractor's license number issued by the State Contractor's Board 0028966
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1191
Signed Mike Davis (By driller performing actual drilling on site or contractor)
Date 11-27-01

(Rev. 3-91)

USE ADDITIONAL SHEETS IF NECESSARY

101-627