WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 85633
Permit No.
Basin 221

NOTICE OF INTENT NO. 21090

1. OWNER Vidler Water Company, Inc.
MAILING ADDRESS 3264 Goni Road, Ste. 153
Carson City, NV 89706

ADDRESS AT WELL LOCATION Tule Desert

2. LOCATION SW ¼ NW ¼ Sec. 4 T. 10 N/(S) R. 69 E. Lincoln County
PERMIT NO. R1087 (Issued by Water Resources) N/A (Parcel No.) N//A (Subdivision Name)

3. WORK PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other

4. PROPOSED USE
[ ] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [X] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [ ] Rotary [X] RVC
[ ] Air [ ] Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Top soil, silt & sand		0	35	35
Sand & gravel		35	135	100
Tan silt & gravel		135	270	135
Light brown clay		270	675	405
Tan clay & gravel	X	675	865	190
Gray rock-limestone		865	885	20
Oxidized gray rock	X	885	955	70
Light gray rock-frac.	X	955	975	20
Gray, tan & brown rock		975	1090	115
Dark gray rock		1090	1140	50
Red brown & tan rock		1140	1160	20
DArk gray rock		1160	1175	15
Same-very fractured	X	1175	1190	15
Hole caved up to 1150'				

Date started January 29, 2002, 19
Date completed FEbruary 5, 2002, 19

7. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [X] Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
92		12

8. WELL CONSTRUCTION
Depth Drilled 1190 Feet Depth Cased 1148.8 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
14.75 Inches		0 Feet	40 Feet
9.875 Inches		40 Feet	1190 Feet
Inches		Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
10.75	28.04	.250	+2	38
5.5	16.7	.300	+1.5	1148.8

Perforations:
Type perforation Milled slot
Size perforation .125
From 1107.8 feet to 1148.8 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 50
Placement Method: [ ] Pumped [X] Poured
Seal Type: [X] Neat Cement [ ] Cement Grout [ ] Concrete Grout

Gravel Packed: [X] Yes [ ] No
From 1074 feet to 1150 feet

9. WATER LEVEL
Static water level 718.32 feet below land surface
Artesian flow No G.P.M. N/A P.S.I.
Water temperature cool °F Quality good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Lang Exploratory Drilling (Contractor)
Address 2745 W. CAlifornia AVe. (Contractor)
Salt Lake City, UT 84104
Nevada contractor's license number issued by the State Contractor's Board 0021976
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2039
Signed Danny Robblee (By driller performing actual drilling on site or contractor)
Date February 6, 2002

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627