

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT
 Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 21093

1. OWNER Vidler Water Company, Inc. ADDRESS AT WELL LOCATION _____
 MAILING ADDRESS 3264 Goni Road Ste #153 50 miles south of Caliente, NV
Carson City, NV 89706-7925 Tule Desert
 2. LOCATION NE 1/4 SW 1/4 Sec 15 T 9 N 8 R 68 E Lincoln County _____
 PERMIT NO. R-1071 Parcel No. N/A Subdivision Name _____
Issued by Water Resources

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Sand & Gravel		0	180	180
Gravel & Clay		180	215	35
Clays		215	530	315
Gravel & Clay		530	715	185
Gravel, Silt and Clay		715	880	165
Dolomite and Limestone		880	1550	670
Shale		1550	1675	125
Sandstone	X	1675	1910	235
Clays & Sandstone		1910	2030	120

8. WELL CONSTRUCTION
 Depth Drilled 2030 Feet Depth Cased 1993 Feet

HOLE DIAMETER (BIT SIZE)
 From To
22 Inches 0 Feet 16 Feet
9 7/8 Inches 16 Feet 2030 Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
SEE ATTACHMENT				

Perforations:
 Type perforation Slotted
 Size perforation 1/8" x 3"

From <u>914</u>	feet to <u>954</u>	feet
From <u>995</u>	feet to <u>1055</u>	feet
From <u>1097</u>	feet to <u>1137</u>	feet
From <u>1475</u>	feet to <u>1505</u>	feet
From <u>cont.</u>	feet to <u>continued</u>	feet

Surface Seal: Yes No Seal Type:
 Neat Cement
 Cement Grout
 Concrete Grout

Depth of Seal 877

Placement Method: Pumped
 Poured

Gravel Packed: Yes No
 From 877 feet to 2030 feet

DCNR/DWR
 RECEIVED
 DEC 10 2001
 LAS VEGAS OFFICE

9. WATER LEVEL
 Static water level 1800 feet below land surface
 Artesian flow N/A G.P.M. N/A P.S.I.
 Water temperature _____ °F Quality _____

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Lang Exploratory Drilling Contractor
 Address 2745 W. California Ave. Contractor
Salt Lake City, UT 84104

Nevada contractor's license number 0021976
 issued by the State Contractor's Board

Nevada driller's license number issued by the 1962
 Division of Water Resources, the on-site driller

Signed [Signature]
 By driller performing actual drilling on site or contractor

Date _____

7. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>10</u>	<u>Bailed well dry</u>	<u>24</u>

Date started October 1, 2001, 19_____
 Date completed October 28, 2001, 19_____

85634

Size O.D. (Inches)	Weight/ Ft (Pounds)	Wall Thickness (Inches)	CASING SCHEDULE	
			From (Feet)	To (Feet)
16"	58	0.325	0	16
5	16	0.375	1	914
5	16	0.375	954	995
5	16	0.375	1055	1097
5	16	0.375	1137	1475
5	16	0.375	1505	1700
5	16	0.375	1760	1804
5	16	0.375	1843	1930

CONTINUED FROM PAGE ONE:
FROM 1700 FEET TO 1760 FEET
FROM 1804 FEET TO 1843 FEET
FROM 1930 FEET TO 1970 FEET