WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 85640
Permit No. ~~62864~~ 68334
Basin 209

NOTICE OF INTENT NO. 13817

1. OWNER Ed Hansen
MAILING ADDRESS #58 Quail Road Hiko NV 89017
ADDRESS AT WELL LOCATION Mike Marker #3 SR 318 Hiko NV

2. LOCATION N/E ¼ N/E ¼ Sec. 34 T. 4 N/S R. 60 E. Lincoln County
PERMIT NO. 62864 Issued by Water Resources
011-090-13 Parcel No.
Subdivision Name —

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☒ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
TOP Soil		0	14	14
Sand - Boulders		14	70	56
Clay-Sand	X	70	110	40
gravel - Boulders	X	110	165	55
Hard Rock		165	172	7
Sand - Gravel	X	172	194	22
Sand	X	194	198	4
Sand - clay		198	209	11
Clay		209	223	14

DCNR/DWR RECEIVED DEC 04 2001 LAS VEGAS OFFICE

Date started 10-30-01, 19
Date completed 11-7-01, 19

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
270		8

8. WELL CONSTRUCTION
Depth Drilled 223 Feet Depth Cased 223 Feet

HOLE DIAMETER (BIT SIZE)

Inches	From Feet	To Feet
14¾	0	223

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
8 5/8		.188	0	223

Perforations:
Type perforation Factory
Size perforation 1/8" x 3"
From 73 feet to 93 feet
From 113 feet to 133 feet
From 153 feet to 173 feet
From 193 feet to 223 feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 50
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☐ Neat Cement ☒ Cement Grout ☐ Concrete Grout

Gravel Packed: ☐ Yes ☐ No
From 50 feet to 223 feet

9. WATER LEVEL
Static water level 63 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature cold °F Quality poor

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Davis Drilling and Pumps (Contractor)
Address HC 61 Box 54 Hiko NV 89017 (Contractor)

Nevada contractor's license number issued by the State Contractor's Board 0025866
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1191
Signed Mike Davis (By driller performing actual drilling on site or contractor)
Date 11-7-01

(Rev. 3-91)

USE ADDITIONAL SHEETS IF NECESSARY

(O)-627