WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

# WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 85651
Permit No.
Basin 212

NOTICE OF INTENT NO. 22155

1. OWNER CLARK CO. SANITATION DISTRICT
MAILING ADDRESS 5825 S. POLARIS AVE.
LAS VEGAS, NV 89193

ADDRESS AT WELL LOCATION 5857 E. FLAMINGO RD.
LAS VEGAS, NV 89122
(SLETTEN CONSTRUCTION)

2. LOCATION N ¼ NW ¼ Sec. 22 T. 21 N/S R. 62 E. CLARK County
PERMIT NO. (Issued by Water Resources) 161-22-101-001 (Parcel No.) CCSD FILTER PROJECT #377 (Subdivision Name)

3. WORK PERFORMED
☐ New Well ☐ Replace ☐ Recondition
☐ Deepen ☒ Abandon ☐ Other

4. PROPOSED USE Dewater
☐ Domestic ☐ Irrigation ☐ Test
☒ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

| Material | Water Strata | From | To | Thickness |
|---|---|---|---|---|
| Abandon 3 dewater wells | | | | |
| Drilled out gravel to depth & pulled out each casing. each filled with 3 yards of 9 sac cement slurry. | | | | |

DCNR/DWR
RECEIVED
DEC 04 2001
LAS VEGAS OFFICE

Date started 11/28/01, 19
Date completed 11/28/01, 19

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

| G.P.M. | Draw Down (Feet Below Static) | Time (Hours) |
|---|---|---|
| | | |

8. WELL CONSTRUCTION
Depth Drilled 55' Feet Depth Cased 55' Feet

HOLE DIAMETER (BIT SIZE)

| | From | To |
|---|---|---|
| 24" Inches | 0 Feet | 55' Feet |
| Inches | Feet | Feet |
| Inches | Feet | Feet |

CASING SCHEDULE

| Size O.D. (Inches) | Weight/Ft. (Pounds) | Wall Thickness (Inches) | From (Feet) | To (Feet) |
|---|---|---|---|---|
| 14 | 36.71 | .250 | 0 | 55 |
| | | | | |

Perforations:
Type perforation Machine
Size perforation 3/16x2 1/2x14 around
From 0 feet to feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☐ Yes ☐ No
Depth of Seal
Placement Method: ☐ Pumped ☐ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☐ Yes ☐ No
From feet to feet

9. WATER LEVEL
Static water level feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F. Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name ALLEN DRILLING INC. (Contractor)
Address 4847 S. VALLEY VIEW (Contractor)
LAS VEGAS, NV 89103
Nevada contractor's license number issued by the State Contractor's Board 18916
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1301
Signed (By driller performing actual drilling on site or contractor)
Date 11/30/01

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY 10)-627