WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

# WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 856662
Permit No.
Basin 102

NOTICE OF INTENT NO. 46316

1. OWNER Roy Clayton
MAILING ADDRESS
ADDRESS AT WELL LOCATION 1170 ANTELOPE ST SILVER SPRINGS, NV

2. LOCATION SW ¼ SW ¼ Sec. 19 T. 17 N/S R. 25 E. LYON County
PERMIT NO. (Issued by Water Resources) Parcel No. 17-422-06 Subdivision Name

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

| Material | Water Strata | From | To | Thickness |
|---|---|---|---|---|
| BROWN CLAY | | 0 | 35 | 35 |
| SANDY BROWN CLAY | | 35 | 62 | 27 |
| FINE GRAVEL | X | 62 | 98 | 36 |
| SANDY BROWN CLAY | | 98 | 118 | 20 |
| COARSE GRAVEL | X | 118 | 140 | 22 |

Date started 23 JAN 02, 19
Date completed 23 JAN 02, 19

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

| G.P.M. | Draw Down (Feet Below Static) | Time (Hours) |
|---|---|---|
| 25+ | | 1.0 |

8. WELL CONSTRUCTION
Depth Drilled 140 Feet Depth Cased 140 Feet

HOLE DIAMETER (BIT SIZE)

| | From | To |
|---|---|---|
| 9 7/8 Inches | 0 Feet | 140 Feet |
| Inches | Feet | Feet |
| Inches | Feet | Feet |

CASING SCHEDULE

| Size O.D. (Inches) | Weight/Ft. (Pounds) | Wall Thickness (Inches) | From (Feet) | To (Feet) |
|---|---|---|---|---|
| 6 5/8 | | .188 | +1 | 140 |

Perforations:
Type perforation Factory milled
Size perforation 3/32" x 3"
From 130 feet to 140 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 50 ft
Placement Method: ☒ Pumped ☐ Poured
Seal Type: ☐ Neat Cement ☒ Cement Grout ☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 50 feet to 140 feet

9. WATER LEVEL
Static water level 38 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature COLD °F Quality CLEAR

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name
Address Blain Drilling & Pump Co. P.O. Box 1255 Carson City, NV 89702
Contractor

Nevada contractor's license number issued by the State Contractor's Board 46498
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2167
Signed Jack Dotson
By driller performing actual drilling on site or contractor
Date

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627