WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 85666
Permit No.
Basin 117

NOTICE OF INTENT NO. 21908

1. OWNER Donald Premys
MAILING ADDRESS PO Box 66, Dyer NV 89010
ADDRESS AT WELL LOCATION West Side of Palmetto Rd Dyer Nevada 89010

2. LOCATION SW ¼ SE ¼ Sec. 8 T. 4 N/S R. 36 E. Esmarlda County
PERMIT NO. (Issued by Water Resources) 07-561-07 (Parcel No.) Wt. Wolf Meadows (Subdivision Name)

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Loose Sand		0	5	5
Gravle & Brown Clay		5	85	80
Granitic Gravle & Sand		85	110	25
Corse Sand & Clay	✓	110	150	40
Brown Clay		150	198	48
Brown Clay & Sand		198	232	34
Granit Bolder		232	234	2
Tan Clay		234	285	51
Loose Sand	✓	285	294	9
Sticky Tan Clay		294	296	2
Hard Rock		299	300	1
White Clay & Corse Sand		300	315	15

DCNR/DWR
RECEIVED
MAR 26 2002
LAS VEGAS OFFICE

Well Final Delayed
Pump test Scaddled & Then Canceled

Date started 9-27- 2001
Date completed 3-18- 2002

7. WELL TEST DATA

TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
200'	37		1
275'	60		2

8. WELL CONSTRUCTION
Depth Drilled 315 Feet Depth Cased 307' Feet

HOLE DIAMETER (BIT SIZE)

	From	To
10 3/4" Inches	0 Feet	315 Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8"	13	.188 Steel	+1	4
6 5/8		F480 SDR21	4	307'

Perforations:
Type perforation Saw Cut
Size-perforation ~~3/4~~ 3/32" X 3" 2 Rows
From 150 feet to 307 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 50'
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☐ Neat Cement ☒ Cement Grout ☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 50 feet to 307' feet

9. WATER LEVEL
Static water level 124' feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality Good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Russell Kile Maranatha Drilling (Contractor)
Address 22893 HWY 6, Benton Ca 93512 (Contractor)
Nevada contractor's license number issued by the State Contractor's Board 0039576
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1238
Signed Russell Kile (By driller performing actual drilling on site or contractor)
Date 3-18-02

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627