WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 85668
Permit No.
Basin 163

NOTICE OF INTENT NO. 22741

1. OWNER JOHN + CHRISTINE JESSEY
MAILING ADDRESS 4841 GRAZINO AV.
LAS VEGAS NV. 89141

ADDRESS AT WELL LOCATION LAVA + POLOMA ST.
SANDY VALLEY NV.

2. LOCATION NE ¼ NW ¼ Sec. 26 T. 24 N/S R. 56 E. CLARK County
PERMIT NO. Issued by Water Resources | Parcel No. 200-26-101-028 | Subdivision Name

3. WORK PERFORMED
☑ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☑ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☑ Rotary ☐ RVC
☑ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
SANDY LOAM		0	2	2
CLAY		2	32	30
CALICHIE		32	36	4
CLAY		36	58	22
CALICHIE		58	64	6
CLAY		64	74	10
CALICHIE	W.B	74	77	3
CLAY		77	88	11
CALICHIE	W.B.	88	92	4
CLAY		92	105	13
CALICHIE	W.B	105	119	14
CLAY		119	128	9
CALICHIE	W.B	128	138	10
CLAY		138	140	2

BOND/DWR
RECEIVED
MAR 21 2002
LAS VEGAS OFFICE

Date started 3-11 2002
Date completed 3-16 2002

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 140 Feet Depth Cased 140 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
10 5/8 Inches	0 Feet	140 Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	4.33	.316	0	140

Perforations:
Type perforation FACTORY SCREEN
Size perforation ¼ INCH BY 3 INCH
From 140 feet to 100 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☑ Yes ☐ No
Depth of Seal 50
Placement Method: ☐ Pumped ☑ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☑ Concrete Grout

Gravel Packed: ☑ Yes ☐ No
From 140 feet to 50 feet

9. WATER LEVEL
Static water level 65 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature COOL °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name BARGET DRILLING CO. (Contractor)
Address P.O. BOX 3505 PAHRUMP NV. 89041 (Contractor)
Nevada contractor's license number issued by the State Contractor's Board 40020
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1523
Signed (By driller performing actual drilling on site or contractor)
Date 3-18-2002

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627