

OFFICE USE ONLY
 Log No. 85679
 Permit No. 212
 Basin 212

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 22760

1. OWNER Samantha Nixon ADDRESS AT WELL LOCATION Vacant 5286 N DAPPLE GRAY RD
 MAILING ADDRESS _____

2. LOCATION SW $\frac{1}{4}$ NW $\frac{1}{4}$ Sec. 32 T. 19S N/S R. 60 E. Clark County
 PERMIT NO. 125-32-206-001
 Issued by Water Resources _____ Parcel No. _____ Subdivision Name _____

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Gravel		0	35	
Cemented Gravel		35	70	
Clay & Gravel		70	275	
Gravel & Water	xx	275	300	
Cemented Gravel		300	360	
Gravel & Water	xx	360	400	
Cemented Gravel		400	460	
Gravel & Water	xx	460	500	

DCNR/DWR
RECEIVED
MAR 07 2002
LAS VEGAS OFFICE

8. WELL CONSTRUCTION
 Depth Drilled 500 Feet Depth Cased 500 Feet

HOLE DIAMETER (BIT SIZE)

From		To	
12 1/4 Inches	0	Feet	55
8 3/4 Inches	55	Feet	500

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
8 3/8	16.94	.188	+1	55
6 1/2	SRD21	PVC	+6"	500

Perforations:
 Type perforation Factory
 Size perforation .032 Sieve Type
 From 460 feet to 500 feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Neat Cement
 Cement Grout
 Concrete Grout

Depth of Seal 55
 Placement Method: Pumped Poured
 Gravel Packed: Yes No
 From _____ feet to _____ feet

9. WATER LEVEL
 Static water level 265 feet below land surface
 Artesian flow _____ G.P.M. _____ F.S.I.
 Water temperature cool °F Quality _____

Date started 11/12/01, 19_____
 Date completed 12/12/01, 19_____
 7. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Vernon H. Dimick Contractor
 Address 5360 Bonita Vista
Las Vegas, Nev. 89149
 Nevada contractor's license number issued by the State Contractor's Board 10062
 Nevada driller's license number issued by the 552 Division of Water Resources, the on-site driller
 Signed V. H. Dimick
 By driller performing actual drilling on site or contractor
 Date 03-06-02