WHITE–DIVISION OF WATER RESOURCES
CANARY–CLIENT'S COPY
PINK–WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

# WELL DRILLER'S REPORT

Please complete this form in its entirety

Log No. 85709
Permit No.
Basin 198

NOTICE OF INTENT NO. 21676

PRINT OR TYPE ONLY

1. OWNER PATRICIA FITZGERALD
MAILING ADDRESS BOX HC 74
PIOCHE NV 89043

ADDRESS AT WELL LOCATION FLATNOSE RANCH ROAD
PIOCHE NEVADA
County LINCOLN

2. LOCATION ¼ SW ¼ Sec. 31 T. 1 N/S R. 69 E.
Subdivision Name
PERMIT NO. Issued by Water Resources
06-291-21 Parcel No.

3. TYPE OF WORK
New Well ☑ Recondition ☐
Deepen ☐ Other ☐

4. PROPOSED USE
Domestic ☑ Irrigation ☐ Test ☐
Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL
Cable ☑ Rotary ☐
Other ☐

6. LITHOLOGIC LOG

| Material | Water Strata | From | To | Thickness |
|---|---|---|---|---|
| SAND & GRAVEL | | 0' | 52' | 52' |
| CEMENTED GRAVEL | | 52' | 58' | ~~54'~~ 6' |
| FINE RED SAND-CLAY MIX | | 58' | 76' | 18' |
| CLEAN SAND & GRAVEL | | 76' | 90' | 14' |
| CIMENTED GRAVEL | | 90' | 94' | 4' |
| SAND & PEA GRAVEL | | 94' | 98' | 4' |
| GRAVEL AND COBBLES | | 98' | 112' | 14' |

DCNR/DWR
RECEIVED
DEC 24 2002
LAS VEGAS OFFICE

Date started 11-24-01, ~~19~~
Date completed 01-20-02, ~~19~~

7. WELL TEST DATA

| Pump RPM | G.P.M. | Draw Down | After Hours Pump |
|---|---|---|---|
| | | | |

BAILER TEST
G.P.M. 14 Draw down 2 feet 2 hours
G.P.M. Draw down feet hours
G.P.M. Draw down feet hours

8. WELL CONSTRUCTION
Diameter 16 inches Total depth 112' feet
10 1/4 inches
8 inches
Casing record 10 3/4" x 54' (+2' STICK-UP)
Weight per foot 32.75# Thickness .250

| Diameter | From | To |
|---|---|---|
| 5" inches | +2' feet | 100' feet |
| inches | feet | feet |
| inches | feet | feet |
| inches | feet | feet |
| inches | feet | feet |
| inches | feet | feet |

Surface seal: Yes ☑ No ☐ Type
Depth of seal 54'
Gravel packed: Yes ☑ No ☐
Gravel packed from 100' feet to 55' feet

Perforations:
Type perforation VERTICAL
Size perforation 1/8" x 6"
From 100' feet to 80' feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

9. WATER LEVEL
Static water level 82' feet below land surface
Flow 14 G.P.M. P.S.I.
Water temperature 57° °F Quality GOOD

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name BUCKEYE DRILLING LLC (Contractor)
Address P.O. BOX 2134, PAHRUMP NV 89041 (Contractor)
Nevada contractor's license number issued by the State Contractor's Board 50941
Nevada contractor's driller's number issued by the Division of Water Resources 2064
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2064
Signed [signature] (By driller performing actual drilling on site or contractor)
Date 12-03-02

USE ADDITIONAL SHEETS IF NECESSARY

(Rev. 11-85)

(O)-627