

STATE OF NEVADA
 DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
 Log No. 85712
 Permit No. 97
 Basin 97

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 43874

1. OWNER JIM & ELISABETH DAY ADDRESS AT WELL LOCATION 835 Monte Vista
 MAILING ADDRESS 5690 Riggins Ct., Ste B Reno, Nevada 89511
Reno, Nevada 89502
 2. LOCATION NW 1/4 SE 1/4 Sec. 7 T 18N N/S R. 20 E Washoe County Washoe
 PERMIT NO. 044-383-04 SW Reno, Sierra Manor
Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other.....
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other.....

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
WELL ABANDONMENT				
Static water level @ 6 feet				
Total depth @ 9 feet				
Casing 24" dia galvanized culvert pipe				
Pull pump & disconnect piping				
Excavate around casing with backhoe & pull 10 ft. length galvanized culvert pipe.				
Backfill with native material.				
This method of abandonment/plugging was approved 2-12-02 by Tim Hunt, State Engineer @DWR.				
Meet with Darrel Avila, Washoe County inspector on site.				
Equipment used: Backhoe				
Materials used: Native material				
Location: 100 ft E of W property line 120 S of N property line				

8. WELL CONSTRUCTION

Depth Drilled..... Feet Depth Cased..... Feet

HOLE DIAMETER (BIT SIZE)

Inches	Feet	Feet
From	To	
.....
.....
.....

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)

Perforations:

Type perforation.....
 Size perforation.....

From	feet to	feet
From.....

Surface Seal: Yes No Seal Type:
 Neat Cement
 Cement Grout
 Concrete Grout

Depth of Seal.....
 Placement Method: Pumped Poured
 Gravel Packed: Yes No
 From..... feet to..... feet

Date started February 22, 2002, 19.....
 Date completed February 22, 2002, 19.....

7. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

9. WATER LEVEL

Static water level..... feet below land surface
 Artesian flow..... G.P.M. P.S.I.
 Water temperature..... °F Quality.....

10. DRILLER'S CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.

Name WAYNE DRILLING, INC. Contractor
 Address P.O. BOX 12370 Contractor
RENO, NEVADA 89510

Nevada contractor's license number issued by the State Contractor's Board 0022549
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 908

Signed [Signature] by driller performing actual drilling on site or contractor
 Date February 25, 2002