

COPIES TO  
 - DIVISION OF WATER RESOURCES  
 - CLIENT'S COPY  
 - WELL DRILLER'S COPY

STATE OF NEVADA  
 DIVISION OF WATER RESOURCES  
**WELL DRILLER'S REPORT**

OFFICE USE ONLY  
 Log No. 85714  
 Permit No. 107  
 Basin 107  
 NOTICE OF INTENT NO. 46394  
21 VALLEY VIEW DR.  
WELLINGTON, NV

PRINT OR TYPE ONLY

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

1. OWNER **KEN & LINDA BAKER**  
 MAILING ADDRESS **21 VALLEY VIEW DR.**  
**WELLINGTON, NV**  
 ADDRESS AT WELL LOCATION **21 VALLEY VIEW DR.**  
**WELLINGTON, NV**

2. LOCATION **NW 1/4 SW 1/4 Sec 2 T 10 N R 23 E** **LYON** County  
 PERMIT NO. **10-661-08** **WELLINGTON, SMITH VALLEY**  
 Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other  
 4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock  
 5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other **MUD**

6. LITHOLOGIC LOG				
Material	Water Strata	From	To	Thick-ness
<b>VOLCANIC GRAVELS</b>		<b>0</b>	<b>6</b>	<b>6</b>
<b>CEMENTED GRAVELS</b>		<b>6</b>	<b>46</b>	<b>40</b>
<b>VOLCANIC</b>				
<b>COBBLES AND VOLCANIC BOULDERS</b>		<b>46</b>	<b>83</b>	<b>37</b>
<b>BROWN CLAY</b>		<b>83</b>	<b>156</b>	<b>73</b>
<b>COURSE SANDS AND VOLCANIC GRAVELS</b>		<b>156</b>	<b>173</b>	<b>17</b>
<b>FRACTURED VOLCANIC GRAVELS</b>	<b>XXX</b>	<b>173</b>	<b>220</b>	<b>47</b>

8. WELL CONSTRUCTION  
 Depth Drilled **220** Feet Depth Cased **220** Feet  
 HOLE DIAMETER (BIT SIZE)  
 From To  
**10 3/4** Inches **0** Feet **220** Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 CASING SCHEDULE  

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<b>6 5/8</b>	<b>13.03</b>	<b>.188</b>	<b>+2</b>	<b>220</b>

Perforations:  
 Type perforation **FACTORY MILL SLOT**  
 Size perforation **3 X 3/32**  
 From **200** feet to **220** feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  
 Depth of Seal **100'**  Neat Cement  
 Placement Method:  Pumped  Cement Grout  
 Poured  Concrete Grout  
 Gravel Packed:  Yes  No  
 From **100** feet to **220** feet

9. WATER LEVEL  
 Static water level **95** feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. **20** P.S.I.  
 Water temperature **WARM 80 °F** Quality **GOOD**

Date started **1/22, 20 02**  
 Date completed **1/25, 20 02**

7. WELL TEST DATE

TEST METHOD:	Bailer	Pump	Air Lift
	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
	Draw Down (Feet Below Static)		Time (Hours)
	<b>20</b>	<b>45</b>	<b>3 HRS</b>

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name **CAPITAL CITY WELL DRILLING**  
 (CONTRACTOR)  
 Address **20 KIT KAT DRIVE**  
 (CONTRACTOR)  
**CARSON CITY, NV 89706**  
 Nevada contractor's license number issued by the State Contractor's Board **41775**  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller **1905**  
 Signed *Michael Z. Hack*  
 By driller performing actual drilling on site or contractor  
 Date **2/02/02**