

PLEASE USE ONLY
 Log No. 85715
 Permit No. 87
 Basin 87

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 37872

1. Consultant: CDM Engineers & Constructors, Inc Client: Santa Fe Pipeline
 MAILING ADDRESS: 7025 Longley Ln, Suite #20 ADDRESS AT WELL LOCATION: Vista Canyon Group Sparks Solvent/Fuel Site
Reno, Nevada 89511 Sparks, Nevada
 2. LOCATION: SE 1/4 NE 1/4 Sec 9 T 19N N/S R 20 E Washoe County
 PERMIT NO. M/O 913 R-1 34-102-14 Sparks Solvent/Fuel Site
Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
MONITOR WELL ABANDONMENT				
Static Water Level:		12 feet		
Total Depth:		77 feet		
Set tremie pipe to bottom of casing				
Pump neat cement from bottom to surface (used 48 sacks)				
Pull tremie, fill casing				
This well was in a cement vault.				
Vault was buried.				
Equipment:				
Service truck, 2 man crew				
High pressure Walnut Grove cement pump & mixer				
75 ft, 1 inch dia tremie pipe				
Materials:				
48 sacks of Portland Cement Type II				
Location:				
Just East of Plan 2 located at 425 E. Nugget Ave				

8. WELL CONSTRUCTION

Depth Drilled..... Feet Depth Cased..... Feet

HOLE DIAMETER (BIT SIZE)

From		To	
..... Inches Feet Feet Feet
..... Inches Feet Feet Feet
..... Inches Feet Feet Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)

Perforations:

Type perforation.....
 Size perforation.....

From.....	feet to.....	feet

Surface Seal: Yes No Seal Type:
 Neat Cement
 Cement Grout
 Concrete Grout

Depth of Seal.....
 Placement Method: Pumped Poured
 Poured

Gravel Packed: Yes No
 From..... feet to..... feet

Date started..... October 5, 1998....., 19.....
 Date completed..... October 5, 1998....., 19.....

7. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

9. WATER LEVEL

Static water level..... feet below land surface
 Artesian flow..... G.P.M. P.S.I.
 Water temperature..... °F Quality.....

10. DRILLER'S CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.

Name..... WAYNE DRILLING, INC. Contractor
 Address..... P.O. BOX 12370 Contractor
 RENO, NEVADA 89510

Nevada contractor's license number 0022549
 issued by the State Contractor's Board.

Nevada driller's license number issued by the Division of Water Resources, the on-site driller..... 908

Signed..... By driller performing actual drilling on site or contractor
 Date..... October 6, 1998