

STATE OF NEVADA
 DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
 Log No. 83-1716
 Permit No. 108
 Basin 108

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 46443

1. OWNER Rogelio Espitia ADDRESS AT WELL LOCATION #14 Cardon Lane
 MAILING ADDRESS BOX 5857 Mammoth Lakes Yellowton

2. LOCATION W 1/4 NW 1/4 Sec 9 T. 13 N/S R. 26 E. L401 County

PERMIT NO. 14-601-12 Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other

6. LITHOLOGIC LOG

| Material | Water Strata | From | To | Thick-ness |
|-------------------------------|--------------|------------|------------|--------------|
| <u>Sand & gravel</u> | | <u>0</u> | <u>50</u> | <u>50 FT</u> |
| <u>clay</u> | | <u>50</u> | <u>60</u> | <u>10 FT</u> |
| <u>Clay sand & gravel</u> | | <u>60</u> | <u>120</u> | <u>60 FT</u> |
| <u>sand & gravel</u> | | <u>120</u> | <u>140</u> | <u>20 FT</u> |

8. WELL CONSTRUCTION
 Depth Drilled 140 Feet Depth Cased 140 Feet

HOLE DIAMETER (BIT SIZE)
 From 10 5/8 Inches To 50 Feet
 From 9 7/8 Inches To 140 Feet

CASING SCHEDULE

| Size O.D. (Inches) | Weight/Ft. (Pounds) | Wall Thickness (Inches) | From (Feet) | To (Feet) |
|--------------------|---------------------|-------------------------|-------------|------------|
| <u>6 5/8</u> | <u>14</u> | <u>1 5/8</u> | <u>+1</u> | <u>140</u> |

Perforations:
 Type perforation factory milled
 Size perforation 3/32

From _____ feet to _____ feet
 From 120 feet to 140 feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Depth of Seal 50 FT Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout

Gravel Packed: Yes No
 From 50 feet to 140 feet

9. WATER LEVEL
 Static water level 48 feet below land surface
 Artesian flow NA G.P.M. P.S.I.
 Water temperature Cold °F Quality clear

Date started 2-7-02, 19____
 Date completed 2-8-02, 19____

7. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift

| G.P.M. | Draw Down (Feet Below Static) | Time (Hours) |
|------------|-------------------------------|---------------|
| <u>30+</u> | <u>NA</u> | <u>1 Hour</u> |

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Enloe Drilling Co. Contractor
 Address Box 22372 Carson City 89121 Contractor

Nevada contractor's license number 4739 A issued by the State Contractor's Board.

Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1878

Signed [Signature]
 By driller performing actual drilling on site or contractor

Date 2-10-02