

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT
 Please complete this form in its entirety in
 accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 454129

1. OWNER Jerry Olson ADDRESS AT WELL LOCATION 49 Lodge Pole Road Smith Nev. 89430
 MAILING ADDRESS 99 Pinson Dr. Wellington Nev. 89444
 2. LOCATION SE 1/4 SE 1/4 Sec. 12 T. 11 N/S.R. 23 E County Lincoln
 PERMIT NO. 9-131-02 Subdivision Name Lodge Pole Road Estates

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other.....
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other.....

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
<u>top soil</u>		<u>0</u>	<u>10</u>	<u>10</u>
<u>hard pan</u>		<u>10</u>	<u>15</u>	<u>5</u>
<u>sand</u>		<u>15</u>	<u>35</u>	<u>20</u>
<u>sandy clay</u>		<u>35</u>	<u>65</u>	<u>30</u>
<u>Coarse sand</u>	<input checked="" type="checkbox"/>	<u>65</u>	<u>106</u>	<u>41</u>
<u>fine gravel</u>	<input checked="" type="checkbox"/>	<u>106</u>	<u>120</u>	<u>14</u>

8. WELL CONSTRUCTION
 Depth Drilled 120 Feet Depth Cased 120 Feet
 HOLE DIAMETER (BIT SIZE)
 From 0 To 50
10 Inches 0 Feet 50 Feet
6 Inches 50 Feet 120 Feet
 Inches Feet Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 5/8</u>		<u>1 8/8</u>	<u>0</u>	<u>120</u>

Perforations:
 Type perforation Hardy saw slott
 Size perforation
 From 80 feet to 120 feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Depth of Seal 50 Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout
 Gravel Packed: Yes No
 From _____ feet to _____ feet

9. WATER LEVEL
 Static water level 55 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature Cold °F Quality good

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Edmund Miller Drilling Co. Contractor
 Address P.O. Box 92 Smith Nev. 89430 Contractor
 Nevada contractor's license number 32166 A
 issued by the State Contractor's Board
 Nevada driller's license number issued by the 718
 Division of Water Resources, the on-site driller
 Signed Edmund Miller
 By driller performing actual drilling on site or contractor
 Date Feb 19-02

Date started Feb 11 1902
 Date completed Feb 15 1902

7. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>20</u>	<u>7</u>	<u>3 hrs</u>