

OFFICE USE ONLY
 Log No. 85718
 Permit No. _____
 Basin. 107

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 45425

1. OWNER Wilber + Mary Paddles ADDRESS AT WELL LOCATION 196 Grand View Ln.
 MAILING ADDRESS 196 Grand View Ln. 18930 Small Nevada
 2. LOCATION SW 1/4 SW 1/4 Sec. 12 T 11 N/S R. 23 E County Clark
 PERMIT NO. 09-071-11 Issued by Water Resources Parcel No. Artist View Ranch Estates Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
<u>sandy loam top soil</u>		<u>0</u>	<u>10</u>	<u>10</u>
<u>hard pan</u>		<u>10</u>	<u>18</u>	<u>8</u>
<u>sandy clay</u>		<u>18</u>	<u>60</u>	<u>42</u>
<u>water sand</u>	<input checked="" type="checkbox"/>	<u>60</u>	<u>110</u>	<u>50</u>
<u>1 sand per gravel</u>				

8. WELL CONSTRUCTION
 Depth Drilled 110 Feet Depth Cased 110 Feet
 HOLE DIAMETER (BIT SIZE)
 From 10 Inches To 50 Feet
6 Inches 50 Feet 110 Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 5/8</u>		<u>1 9/8</u>	<u>0</u>	<u>110</u>

Perforations:
 Type perforation flexible wire slotted
 Size perforation 3/32 x 3
 From 70 feet to 110 feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Neat Cement
 Cement Grout
 Concrete Grout
 Depth of Seal _____
 Placement Method: Pumped Poured
 Gravel Packed: Yes No
 From _____ feet to _____ feet

9. WATER LEVEL
 Static water level: 50 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature Cold °F Quality good

Date started Feb 6 1902
 Date completed Feb 7 1902

7. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>20</u>	<u>10 ft</u>	<u>3 hrs.</u>

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Edmund Miller Drilling Contractor
 Address P.O. Box 92 Smith Grov.
 Nevada contractor's license number 32166A issued by the State Contractor's Board.
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 718
 Signed Edmund Miller
 By driller performing actual drilling on site or contractor
 Date Feb 11 - 02