

OFFICE USE ONLY
 Log No. 85779
 Permit No. 108
 Basin

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 44556

1. OWNER Richard Atwood ADDRESS AT WELL LOCATION Wyatt Dr
 MAILING ADDRESS Yepitan
48 Wyatt Dr., Yerington, NV.
 2. LOCATION SE 1/4 SE 1/4 Sec 8 T 12 NS R 25 E Parcel D County
 PERMIT NO. 12-231-48 Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Boulders		0	26	
Boulders & Gravel		26	76	
Coarse Sand		76	110	
Boulders Gravel		110	136	
Sand coarse		136	162	
Gravel Boulders		162	260	260

8. WELL CONSTRUCTION
 Depth Drilled 260 Feet Depth Cased 257 Feet

HOLE DIAMETER (BIT SIZE)
 From 0 To 260
10578 Inches 0 Feet 260 Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6578</u>	<u>1300</u>	<u>3/16</u>	<u>11</u>	<u>20</u>
<u>6578</u>	<u>3000</u>	<u>1/4</u>	<u>20</u>	<u>257</u>

Perforations:
 Type perforation Soil Saw
 Size perforation 1 1/4 x 6 Long S. Holes
 From 197 feet to 257 feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Neat Cement
 Cement Grout
 Concrete Grout

Depth of Seal 0-50
 Placement Method: Pumped Poured
 Gravel Packed: Yes No
 From 75 feet to 257 feet

9. WATER LEVEL
 Static water level 95 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature _____ °F. Quality _____

Date started 3-13-
 Date completed 3-15-

7. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>40</u>	<u>6 PM</u>	

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Leah Phillips Inc
 Address PO Box 579
Shenandoah NV 89429
 Nevada contractor's license number 0031241
 issued by the State Contractor's Board.
 Nevada driller's license number issued by the 1977
 Division of Water Resources, the on-site driller.
 Signed Michael J. Leah
 By driller performing actual drilling on site or contractor
 Date 3-15-02