

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

office use only
Log No. 85137
Permit No. 87
Basin
NOTICE OF INTENT NO 47810
6150 Melarkey Rd.

1. OWNER **Gerald L. Avery**
MAILING ADDRESS **1040 Meadow St.
Reno NV 89509**

ADDRESS AT WELL LOCATION

6150 Melarkey Rd.

2. Location **NW 1/4 SW 1/4 Sec 26 T 18N R 19E Washoe County**
PERMIT NO. **WAIVER LETTER NEV. 2001** PARCEL NO. **150-260-01** SUBDIVISION NAME

3. WORK PERFORMED: New Well, Replace, Recondition, Deepen, Abandon, Other
4. PROPOSED USE: Domestic, Irrigation, Test, Monitor, Municipal/Industrial, Stock
5. WELL TYPE: Cable, Rotary, RVC, Air, Other, Mud

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
clay and boulder		0	63	63
fractured rock		63	77	14
rock & clay		77	105	28
rock		105	144	39
brown clay & rock		144	300	156
lost circulation		300	385	85

8. WELL CONSTRUCTION

Depth Drilled	385 feet	Depth Cased	385 feet
HOLE DIAMETER (BIT SIZE)			
	From	To	
10 5/8 inches	0 feet	100 feet	100 feet
8 3/4 inches	100 feet	385 feet	385 feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	12.94	188	+1 1/2	385

Perforations:

Type Perforation	Factory
Size perforation	3/32 x 3"
From 285 feet to 305 feet	
From 325 feet to 345 feet	
From 365 feet to 385 feet	

Surface Seal YES No Seal Type:
Depth of Seal 100 feet Neat Cement
 Pumped Cement Grout
 Poured Concrete Grout
Gravel Packed: Yes No
From 100 feet to 385 feet

N 39.395541
W 119.825379 NAD27
Deepend under NDI 61156

9. WATER LEVEL
Static water leve 350 feet below land surface
Artesian flow 0 GPM 0 P.S.I.
Water Temperature cold Degrees F Quality

Date started 2-19 -02
Date completed 3-8 -02

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name McKay Drilling, Inc.
2290 Pioneer Drive
Reno, NV 89509
NV Contractors No. 14170
NV Driller's Lic (on site) 2121
Signed *[Signature]*
By driller performing actual drilling on site or contractor
Date 3-12 -02

7. WELL TEST DATA

TEST METHOD:	Bailer	Pump	x	Air Lift
G.P.M.	Draw Down (Feet Below Static)	Time (hours)		
5	30			
10	35	6		