

STATE OF NEVADA
 DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE-USE ONLY
 Log No. 8528
 Permit No. _____
 Basin 162
 NOTICE OF INTENT NO. 22350

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

1. OWNER Charles Held ADDRESS AT WELL LOCATION _____
 MAILING ADDRESS 1550 E. Santovito 1550 E. Santovito
Pahrump, NV 89048
 2. LOCATION SW 1/4 SE 1/4 Sec. 14 T 21S N/S R 53E E Nye County
 PERMIT NO. 44-742-07 Mesa Oeste Estates
 Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED 4. PROPOSED USE 5. WELL TYPE
 New Well Replace Recondition Domestic Irrigation Test Cable Rotary RVC
 Deepen Abandon Other Municipal/Industrial Monitor Stock Air Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
brown loam		0	5	5
brown caleche		5	34	29
See next line	x	34	37	3
brown clay with caleche strings				
See next line		37	76	39
grey clay with caleche strings				
See next line		76	91	15
brown clay with caleche strings				
See next line	x	91	155	64
grey clay with caleche strings				
brown loam	x	155	200	45

DCNR/DWR
RECEIVED
APR 08 2002
LAS VEGAS OFFICE

8. WELL CONSTRUCTION
 Depth Drilled 200 Feet Depth Cased 200+1 Feet
 HOLE DIAMETER (BIT SIZE)
 From To
11 Inches 0 Feet 200 Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	3.7	.280	0	200

Perforations:
 Type perforation sawcut
 Size perforation .188
 From 180 feet to 200 feet
 From _____ feet to _____ feet
 Surface Seal: Yes No Seal Type:
 Depth of Seal 50 Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout
 Gravel Packed: Yes No
 From 50 feet to 200 feet

9. WATER LEVEL
 Static water level 98 feet below land surface
 Artesian flow _____ G.P.M. P.S.I.
 Water temperature cool °F Quality good

Date started 2/22/02, 19____
 Date completed 2/22/02, 19____

7. WELL TEST DATA

TEST METHOD:	Bailer	Pump	Air Lift
G.P.M.	Draw Down (Feet Below Static)	Time (Hours)	

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Strickland Construction Co., Inc. Contractor
 Address 5801 S. Homestead Contractor
Pahrump, NV 89048
 Nevada contractor's license number issued by the State Contractor's Board 40277
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2086
 Signed _____
 By driller performing actual drilling on-site or contractor
 Date 3-25-02