WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 85827
Permit No.
Basin 212

NOTICE OF INTENT NO. 21733

1. OWNER LV Paving
MAILING ADDRESS 4420 S Decatur LV NV

ADDRESS AT WELL LOCATION Flaming Wash-West of Boulder Hiway between Boulder & Mojave

2. LOCATION SE ¼ NW ¼ Sec. 7 T. 21 N(S) R 62 E. Clarke County
PERMIT NO. DW1138 (Issued by Water Resources) | 161-07-296-001 (Parcel No.) | Flamingo Wash (Subdivision Name)

3. WORK PERFORMED
☐ New Well ☐ Replace ☐ Recondition
☐ Deepen ☒ Abandon ☐ Other

4. PROPOSED USE (Temp Dewater)
☐ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☐ Air ☒ Other Bucket

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
— Abandon 9 wells in Flamingo Wash				
— Pull Casing, Vaccum gravel pack from surface to 10' below working surface. Gravity pour cement grout from 10' below working surface to top.				

DCNR/DWR
RECEIVED
JAN 0 2 2002
LAS VEGAS OFFICE

Date started 1-29-02, 1902
Date completed 1-29-02, 1902

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 25 Feet Depth Cased 25 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
24 Inches	0 Feet	25 Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
8	PVC	Sch 40	0	25

Perforations:
Type perforation Slot
Size perforation .030
From 5 feet to 25 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 10' from working surface
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☐ Neat Cement ☒ Cement Grout ☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 10 feet to 25 feet

9. WATER LEVEL
Static water level 12 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature Cool °F Quality good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Grillin Dewatering (Contractor)
Address 537 E Maitland (Contractor)
Ontario Ca
Nevada contractor's license number issued by the State Contractor's Board 0031246
Nevada driller's license number issued by the Division of Water Resources, the on-site driller ABDS-2150
Signed [signature] (By driller performing actual drilling on site or contractor)
Date 1-29-02

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627