

OFFICE USE ONLY
 Log No. 85837
 Permit No. _____
 Basin 162

NOTICE OF INTENT NO. 22343

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

1. OWNER Jerry Bledsoe ADDRESS AT WELL LOCATION _____
 MAILING ADDRESS 440 E. Wilson 440 E. Wilson
Pahrump, NV 89048

2. LOCATION SE 1/4 SE 1/4 Sec. 15 T 20S N/S R 53E E NYE County
 PERMIT NO. 35-321-02 Nye
 Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED 4. PROPOSED USE 5. WELL TYPE

X New Well Replace Recondition Domestic Irrigation Test
 Deepen Abandon Other Municipal/Industrial Monitor Stock Cable Rotary RVC
 Air Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
brown clay		0	3	3
grey loam		3	6	3
brown loam	x	6	84	78
brown caleche	x	84	88	4
See next line	x	88	107	19
brown loam with caleche strings				
brown caleche	x	107	109	2
See next line	x	109	159	50
brown loam with caleche strings				
brown caleche	x	159	166	7
See next line	x	166	200	34
brown loam with caleche strings				

DCNR/DWR
RECEIVED
APR 08 2002
LAS VEGAS OFFICE

8. WELL CONSTRUCTION

Depth Drilled 200 Feet Depth Cased 200+1 Feet

HOLE DIAMETER (BIT SIZE)

From 0 To 200
11 Inches Feet 200 Feet
 _____ Inches Feet _____ Feet
 _____ Inches Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	3.7	.280	0	200

Perforations:
 Type perforation sawcut
 Size perforation .188

From 180 feet to 200 feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Depth of Seal 50 Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout

Gravel Packed: Yes No
 From 50 feet to 200 feet

9. WATER LEVEL

Static water level 52 feet below land surface
 Artesian flow _____ G.P.M. P.S.I.: _____
 Water temperature cool °F Quality good

Date started 2/20/02 19____
 Date completed 2/20/02 19____

7. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

10. DRILLER'S CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Strickland Construction Co., Inc. Contractor
 Address 5801 S. Homestead Contractor
Pahrump, NV 89048

Nevada contractor's license number issued by the State Contractor's Board 40277

Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2086

Signed Jerry Bledsoe
 By driller performing actual drilling on-site of contractor

Date 3-25-02