

STATE OF NEVADA
 DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
 Log No. 85841
 Permit No. _____
 Basin 164A

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 22914

1. OWNER Las Vegas Paving Corp. ADDRESS AT WELL LOCATION I-15 at Jean NV
 MAILING ADDRESS 4420 South Decatur Blvd.
Las Vegas, NV 89103

2. LOCATION NW 1/4 SW 1/4 Sec. 12 T 25S N/S R 59E E Clark County
 PERMIT NO. C-1022 217-12-301-002 na
Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Loose Rock and Dirt		0	3	3
Sandy clay and gravel		3		
mix			220	217
clay and gravel with layers of cemented gravel			300	80
Clay and gravel		300	480	180
sandy clay and gravel	x	480	600	120
cemented sand and gavel with fractures	x	600	835	235

DCNR/DWR
RECEIVED

FEB 04 2002

LAS VEGAS OFFICE

8. WELL CONSTRUCTION
 Depth Drilled 835 Feet Depth Cased 835 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
17 3/4 Inches	0	10
12 Inches	-10	60
11 Inches	60	835

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
12 3/4	24	.188	0	10
8 5/8	16.94	.188	0	835

Perforations:
 Type perforation SAW
 Size perforation 1/8 by 3 inch

From	feet to	feet
From <u>675</u>	feet to	<u>815</u> feet
From _____	feet to	_____ feet
From _____	feet to	_____ feet
From _____	feet to	_____ feet
From _____	feet to	_____ feet

Surface Seal: Yes No Seal Type:
 Depth of Seal 60 ft. Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout

Gravel Packed: Yes No
 From 60 feet to 835 feet

Date started 11/26/2001 19__
 Date completed 11/30/2001 19__

7. WELL TEST DATA

TEST METHOD:	G.P.M.		Time (Hours)
	Bailer	Pump	
	Draw Down (Feet Below Static)		

9. WATER LEVEL
 Static water level 450 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature _____ °F Quality _____

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.

Name GREAT BASIN DRILLING CO. OF NEVADA, INC. Contractor
 Address P.O. BOX 4220 Contractor
PAHRUMP, NV. 89048

Nevada contractor's license number issued by the State Contractor's Board 47333
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1426

Signed [Signature]
 By driller performing actual drilling on-site or contractor
 Date 12/17/2001