

OFFICE USE ONLY  
 Log No. 85832  
 Permit No. \_\_\_\_\_  
 Basin 212

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 21733

1. OWNER L.V. Faving ADDRESS AT WELL LOCATION FLAMINGO WASH  
 MAILING ADDRESS 4420 S. Decatur WEST OF BOULDER Hiway - EAST OF  
LV NV Mojave St.

2. LOCATION SE 1/4 NW 1/4 Sec. 7 T 21 N 62 E CLARKE County  
 PERMIT NO. DW1138 161-07-296-001 Flamingo Wash Subdivision Name

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other \_\_\_\_\_

4. PROPOSED USE Temp. Dewell 5. WELL TYPE  
 Domestic  Irrigation  Test  Cable  Rotary  RVC  
 Municipal/Industrial  Monitor  Stock  Air  Other BUCKET

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
<u>Abandon 7 wells (12)</u>				
<u>Vacuum gravel pack from</u>				
<u>working surface to 10' - Gravel,</u>				
<u>pour cement from 10' to</u>				
<u>working surface for seal</u>				
<u>This procedure done on</u>				
<u>all 7 wells.</u>				
DCNR/DWR RECEIVED MAR 13 2002 LAS VEGAS OFFICE				

8. WELL CONSTRUCTION  
 Depth Drilled 25 Feet Depth Cased 25 Feet

HOLE DIAMETER (BIT SIZE)  
24" Inches From 0 Feet To 25 Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>8"</u>	<u>PVC</u>	<u>Sch 40</u>	<u>0</u>	<u>25</u>

Perforations:  
 Type perforation slot  
 Size perforation .030

From 5 feet to 25 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  
 Depth of Seal 10'  Neat Cement  
 Placement Method:  Pumped  Cement Grout  
 Poured  Concrete Grout

Gravel Packed:  Yes  No  
 From 0 feet to 25 feet

9. WATER LEVEL  
 Static water level 12 feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature cool °F Quality good

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name GRIFFIN DENATERING Contractor  
 Address 536 E. MAITLAND Contractor  
Ontario Ca.  
 Nevada contractor's license number 0031246  
 issued by the State Contractor's Board.  
 Nevada driller's license number issued by the ABDS-2150  
 Division of Water Resources, the on-site driller.  
 Signed [Signature]  
 By driller performing actual drilling on site or contractor  
 Date 3-12-02

Date started 3-12 7:00  
 Date completed 3-12 19:02

7. WELL TEST DATA

TEST METHOD:  Bailer  Pump  Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)