WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

# WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 85937
Permit No.
Basin 212

NOTICE OF INTENT NO. 21120

1. OWNER CLARK CO. SANITATION DISTRICT
MAILING ADDRESS 5857 EAST FLAMINGO RD.
LAS VEGAS, NEVADA 89112

ADDRESS AT WELL LOCATION
5857 EAST FLAMINGO RD.
LAS VEGAS, NEVADA 89112

2. LOCATION SW ¼ NE ¼ Sec. 22 T. 21 N/S R. 62 E. CLARK County
PERMIT NO. DW 1133A (Issued by Water Resources) 161-22-101-001 (Parcel No.) Subdivision Name

3. WORK PERFORMED
☐ New Well ☐ Replace ☐ Recondition
☐ Deepen ☒ Abandon ☐ Other

4. PROPOSED USE DEWATERING
☐ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☐ Air ☒ Other AUGER

6. LITHOLOGIC LOG

| Material | Water Strata | From | To | Thickness |
|---|---|---|---|---|
| 28 WELLS | | | | |
| BROWN SANDY CLAY | | 0 | 17 | 17 |
| FINE SILTY SAND W/ BROWN SANDY CLAY LAYERS | | 17 | 38 | 21 |

Date started 12-3-01, 19
Date completed 1-25-02, 19

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

| | G.P.M. | Draw Down (Feet Below Static) | Time (Hours) |
|---|---|---|---|
| | | | |

8. WELL CONSTRUCTION
Depth Drilled 38 Feet Depth Cased 37 Feet

HOLE DIAMETER (BIT SIZE)
36 Inches From 0 Feet To 38 Feet
Inches Feet Feet
Inches Feet Feet

CASING SCHEDULE

| Size O.D. (Inches) | Weight/Ft. (Pounds) | Wall Thickness (Inches) | From (Feet) | To (Feet) |
|---|---|---|---|---|
| 12 | 33 | 250 | 0 | 5 |

Perforations:
Type perforation LOUVERED
Size perforation .040
From 5 feet to 37 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 11
Placement Method: ☒ Pumped ☐ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☒ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 11 feet to 38 feet

9. WATER LEVEL
Static water level 5 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name KELLEY DEWATERING CONSTRUCTION CO. (Contractor)
Address 5175 CLAY AVE (Contractor)
WYOMING, MICHIGAN 49548
Nevada contractor's license number issued by the State Contractor's Board S0826-C23
Nevada driller's license number issued by the Division of Water Resources, the on-site driller ABDS-2149
Signed [signature] (By driller performing actual drilling on site or contractor)
Date 2-13-02

USE ADDITIONAL SHEETS IF NECESSARY

(Rev. 3-01) (O)-627