

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT  
 Please complete this form in its entirety in  
 accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 21124

1. OWNER CLARK CO. SANITATION DIST. ADDRESS AT WELL LOCATION \_\_\_\_\_  
 MAILING ADDRESS 5857 EAST FLAMMING RD. \_\_\_\_\_  
LAS VEGAS, NEVADA 89112 \_\_\_\_\_  
 2. LOCATION NW 1/4 NW 1/4 Sec 23 T21 N8 R 62 E County CLARK  
 PERMIT NO. DW-1130 Parcel No. 06122101001 Subdivision Name \_\_\_\_\_

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other \_\_\_\_\_  
 4. PROPOSED USE DEWATERING  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock

6. LITHOLOGIC LOG

| Material                                   | Water Strata                        | From      | To        | Thick-ness |
|--|-------------------------------------|-----------|-----------|------------|
| <u>GS WELLS</u>                            |                                     |           |           |            |
| <u>BRN SANDY CLAY</u>                      |                                     | <u>0</u>  | <u>12</u> | <u>12</u>  |
| <u>CALICHE W/ SAND &amp; GRAVEL LAYERS</u> | <input checked="" type="checkbox"/> | <u>12</u> | <u>31</u> | <u>21</u>  |
| <u>SOFT GRAI CLAY</u>                      |                                     | <u>33</u> | <u>38</u> |            |

8. WELL CONSTRUCTION  
 Depth Drilled 38 Feet Depth Cased 37 Feet  
 HOLE DIAMETER (BIT SIZE)  
 From 20 Inches To 0 Feet 38 Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet

CASING SCHEDULE

| Size O.D. (Inches) | Weight/Ft. (Pounds) | Wall Thickness (Inches) | From (Feet) | To (Feet) |
|--------------------|---------------------|-------------------------|-------------|-----------|
| <u>12</u>          | <u>33</u>           | <u>250</u>              | <u>0</u>    | <u>5</u>  |

Perforations:  
 Type perforation LOUVERED  
 Size perforation 040  
 From 5 feet to 37 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  
 Depth of Seal 11'  Neat Cement  
 Placement Method:  Pumped  Concrete Grout  
 Poured  
 Gravel Packed:  Yes  No  
 From 11 feet to 38 feet

9. WATER LEVEL  
 Static water level 5 feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature \_\_\_\_\_ °F Quality \_\_\_\_\_

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name KELLEY DEWATERING & CONSTRUCTION CO. Contractor  
 Address 5175 CLAY AVE Contractor  
WYOMING, MICH. 49548

Date started 9-11-01 19\_\_\_\_  
 Date completed 11-14-01 19\_\_\_\_

7. WELL TEST DATA

| TEST METHOD: | Bailer                        | Pump         | Air Lift |
|--------------|-------------------------------|--------------|----------|
| G.P.M.       | Draw Down (Feet Below Static) | Time (Hours) |          |
|              |                               |              |          |

Nevada contractor's license number issued by the State Contractor's Board 50826  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller ABDS-2149  
 Signed Justin G. Elson  
 By driller performing actual drilling on site or contractor  
 Date 12-14-01