WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

# WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 85982
Permit No.
Basin 212

NOTICE OF INTENT NO. 21124

1. OWNER CLARK CO. SANITATION DIST.
MAILING ADDRESS 5857 EAST FLAMMINGO RD.
LAS VEGAS, NEVADA 89112

ADDRESS AT WELL LOCATION

2. LOCATION NW ¼ NW ¼ Sec. 2322 T 21 N/S R 62 E CLARK County
PERMIT NO. DW-1130 (Issued by Water Resources) Parcel No. 16122101001 Subdivision Name

3. WORK PERFORMED
☐ New Well ☐ Replace ☐ Recondition
☐ Deepen ☒ Abandon ☐ Other

4. PROPOSED USE DEWATERING
☐ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

| Material | Water Strata | From | To | Thickness |
|---|---|---|---|---|
| 63 WELLS | | | | |
| BRN SANDY CLAY | | 0 | 12 | 12 |
| CALICHE W/ SAND & GRAVEL LAYERS | ✓ | 12 | 31 | 21 |
| SOFT GRAY CLAY | | 33 | 38 | |

DCNR/DWR
RECEIVED
DEC 26 2001
LAS VEGAS OFFICE

Date started 9-11-01, 19
Date completed 11-14-01, 19

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

| G.P.M. | Draw Down (Feet Below Static) | Time (Hours) |
|---|---|---|
| | | |

8. WELL CONSTRUCTION
Depth Drilled 38 Feet Depth Cased 37 Feet

HOLE DIAMETER (BIT SIZE)

| | | From | To |
|---|---|---|---|
| 20 Inches | | 0 Feet | 38 Feet |
| Inches | | Feet | Feet |
| Inches | | Feet | Feet |

CASING SCHEDULE

| Size O.D. (Inches) | Weight/Ft. (Pounds) | Wall Thickness (Inches) | From (Feet) | To (Feet) |
|---|---|---|---|---|
| 12 | 33 | .250 | 0 | 5 |

Perforations:
Type perforation LOUVERED
Size perforation .040
From 5 feet to 37 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☑ Yes ☐ No
Depth of Seal 11'
Placement Method: ☐ Pumped ☐ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☒ Concrete Grout

Gravel Packed: ☑ Yes ☐ No
From 11 feet to 38 feet

9. WATER LEVEL
Static water level 5 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name KELLEY DEWATERING & CONSTRUCTION CO. (Contractor)
Address 5175 CLAY AVE (Contractor)
WYOMING, MICH. 49548
Nevada contractor's license number issued by the State Contractor's Board 50826
Nevada driller's license number issued by the Division of Water Resources, the on-site driller ABDS-2149
Signed (By driller performing actual drilling on site or contractor)
Date 12-14-01

(Rev. 3-91)

USE ADDITIONAL SHEETS IF NECESSARY

(O)-627