WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 86047
Permit No.
Basin 212

NOTICE OF INTENT NO. 22772

1. OWNER Tom Matyas
MAILING ADDRESS

ADDRESS AT WELL LOCATION Vacant N.W. Corner of Dapper Gray and Lone Mountain Rd

2. LOCATION SW ¼ SW ¼ Sec 32 T 19S N/S R 60 E Clark County
PERMIT NO. (Issued by Water Resources) 125-32-405-008 (Parcel No.) (Subdivision Name)

3. WORK PERFORMED
[x] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other

4. PROPOSED USE
[x] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [ ] Rotary [ ] RVC
[x] Air [ ] Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Gravel		0	2	
Cemented Gravel		2	6	
Clay & Gravel		6	125	
Cemented Gravel		125	130	
Clay & Gravel		130	350	
Gravel & Water	xx	350	355	
Cemented Gravel		355	430	
Gravel & Water	xx	430	460	
Cemented Gravel		460	500	
Clay & Gravel		500	540	
Gravel & Water	xx	540	560	
Cemented Gravel		560	620	
Gravel & Water	xx	620	660	

DCNR/DWR RECEIVED MAY 03 2002 LAS VEGAS OFFICE

Date started 4/23/02, 19
Date completed 4/26/02, 19

7. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [ ] Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 660 Feet Depth Cased 660 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
12 1/4	Inches	0 Feet	50 Feet
10 5/8	Inches	50 Feet	660 Feet
	Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
8 5/8	16.94	.188	+2	50
6 1/2	SDR PVC		+1	660

Perforations:
Type perforation Factory
Size perforation .030
From 610 feet to 650 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: [x] Yes [ ] No
Depth of Seal 50
Placement Method: [ ] Pumped [x] Poured
Seal Type: [ ] Neat Cement [ ] Cement Grout [x] Concrete Grout
Gravel Packed: [ ] Yes [x] No
From feet to feet

9. WATER LEVEL
Static water level 335 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature cool °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Vernon H. Dimick (Contractor)
Address 5360 Bonita Vista (Contractor)
Las Vegas, Nev. 89149
Nevada contractor's license number issued by the State Contractor's Board 10062
Nevada driller's license number issued by the Division of Water Resources, the on site driller 552
Signed V H Dimick (By driller performing actual drilling on site or contractor)
Date 04-29-02

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627