WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 86096
Permit No.
Basin 102

NOTICE OF INTENT NO. 47283

1. OWNER Rachel Novak
MAILING ADDRESS
ADDRESS AT WELL LOCATION 8580 Sycamore St. Silver Springs, NV.

2. LOCATION NW ¼ SE ¼ Sec. 21 T. 17 N/S R. 25 E. Lyon County
PERMIT NO. Issued by Water Resources | Parcel No. 17-511-19 | Subdivision Name River Valley View Lot 17

3. WORK PERFORMED
☑ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☑ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☑ Rotary ☐ RVC
☐ Air ☑ Other Mud

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Sand		0	28	
Course Sand		28	32	
Gray Clay		32	78	
Sand Silt Clay		73	118	
Sand Course Sand		118	137	
Gray Clay		137	148	
Sand Clay mix		148	176	
Gravel Sand		176	216	
Clay		216	228	
Gravel	✓	228	238	
Clay		238	240	

Date started 2-18 2002
Date completed 2-19 2002

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☑ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
Produced about 40		

8. WELL CONSTRUCTION
Depth Drilled 240 Feet Depth Cased 240 Feet

HOLE DIAMETER (BIT SIZE)
10 5/8 Inches From 0 Feet To 240 Feet
Inches Feet Feet
Inches Feet Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	13.00	3/16	+1	20
6 5/8	3.00	Sch 40	20	240

Perforations:
Type perforation Scill Saw
Size perforation 1/4 x 6 Lows 5 Rows
From 220 feet to 240 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☑ Yes ☐ No
Depth of Seal 0-50
Placement Method: ☑ Pumped ☐ Poured
Seal Type: ☐ Neat Cement ☑ Cement Grout ☐ Concrete Grout

Gravel Packed: ☐ Yes ☐ No
From 50 feet to 240 feet

9. WATER LEVEL
Static water level 35 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Leach Drilling Inc (Contractor)
Address Po Box 599 (Contractor)
Silver Springs NV 89429
Nevada contractor's license number issued by the State Contractor's Board 0031841
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1877
Signed [signature] By driller performing actual drilling on site or contractor
Date 2-19-02

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627