

COPIES TO  
 - DIVISION OF WATER RESOURCES  
 - CLIENT'S COPY  
 - WELL DRILLER'S COPY

STATE OF NEVADA  
 DIVISION OF WATER RESOURCES  
**WELL DRILLER'S REPORT**

OFFICE USE ONLY  
 Log No. 860917  
 Permit No. 103  
 Basin 103

PRINT OR TYPE ONLY

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 42039  
 ADDRESS AT WELL LOCATION 44 RIVER VISTA RD  
DAYTON, NV 89403

1. OWNER JOE & SUSAN LEWIS  
 MAILING ADDRESS 38 NORTH "C" STREET  
VIRGINA CITY, NV 89440

ADDRESS AT WELL LOCATION 44 RIVER VISTA RD  
DAYTON, NV 89403

2. LOCATION NE 1/4 NE 1/4 Sec 26 T 16 N R 21 E DOUGLAS County  
 PERMIT NO. 19/621/06

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other

4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock

5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other MUD

6. LITHOLOGIC LOG				
Material	Water Strata	From	To	Thickness
<b>HARD BLACK VOLCANIC GRAVELS</b>		0	45	45
<b>COBBLES AND BLACK SLATE</b>		45	110	65
<b>COURSE BLACK OBSIDIAN SANDS AND VOLCANIC GRAVELS</b>		110	169	59
<b>VERY HARD AND FRACTURED VOLCAN. SANDS AND GRAVELS</b>	XXX	169	210	41

8. WELL CONSTRUCTION				
Depth Drilled	<u>210</u> Feet	Depth Cased	<u>210</u> Feet	
HOLE DIAMETER (BIT SIZE)				
	From		To	
	<u>10 3/4</u> Inches	<u>0</u> Feet	<u>210</u> Feet	
	Inches	Feet	Feet	
	Inches	Feet	Feet	
CASING SCHEDULE				
Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 5/8</u>	<u>13.03</u>	<u>.188</u>	<u>+2</u>	<u>210</u>

Perforations:  
 Type perforation FACTORY MILL SLOT  
 Size perforation 3 X 3/32  
 From 190 feet to 210 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  
 Depth of Seal 100  Neat Cement  
 Placement Method:  Pumped  Cement Grout  
 Poured  Concrete Grout  
 Gravel Packed:  Yes  No  
 From 100 feet to 210 feet

9. WATER LEVEL  
 Static water level 60 feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. 25 P.S.I.  
 Water temperature COLD °F Quality GOOD

Date started 2/22, 20 02  
 Date completed 2/27, 20 02

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name CAPITAL CITY WELL DRILLING  
 (CONTRACTOR)  
 Address 20 KIT KAT DRIVE  
 (CONTRACTOR)  
CARSON CITY, NV 89706  
 Nevada contractor's license number issued by the State Contractor's Board 41775  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1905  
 Signed Michael Black  
 By driller performing actual drilling on site or contractor  
 Date 3/1/02

7. WELL TEST DATE			
TEST METHOD:	<input type="checkbox"/> Bailer	<input type="checkbox"/> Pump	<input checked="" type="checkbox"/> Air Lift
	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
	<u>25</u>	<u>45</u>	<u>3 HRS</u>