WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 36111
Permit No.
Basin 102

NOTICE OF INTENT NO. 46725

1. OWNER Nevada Wood Preserving, Ron Sallot
MAILING ADDRESS Pacific Wood Preserving Companies 5601 District Blvd. Bakersfield CA.
ADDRESS AT WELL LOCATION Nevada Wood Preserving, 1680 Spruce Ave. Silver Springs, NV.

2. LOCATION NE ¼ SW ¼ Sec 30 T 18 N/S R 25 E Lyons County
PERMIT NO. NDEP#NV0022501 Issued by Water Resources
Parcel No.
Subdivision Name

3. WORK PERFORMED
☒ New Well ☒ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☒ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☐ Air ☒ Other HSA

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Sand Yellowish Tan		0'	25'	25'
Brown silt & some clay		25'	35'	10'
sandy silt - wet		35'	45'	10'
Blue clay		45'	108'	63'
Cemented Sand & gravel		108'	120'	12'

Date started 2-27-02, 19
Date completed 2-28-02, 19

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION 0-100' Blank PVC
Depth Drilled 120 Feet Depth Cased 100'-120' Screen Feet PVC

HOLE DIAMETER (BIT SIZE)

	From	To
10½ Inches	0 Feet	120' Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
4"		S.40	0	100

Perforations:
Type perforation Factory slot/long year
Size perforation .020
From 100 feet to 120 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 50'
Placement Method: ☒ Pumped ☐ Poured
Seal Type: ☒ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 120 feet to 55' feet

9. WATER LEVEL
Static water level 41 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature <85° °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Haz-Tech Drilling Inc. Contractor
Address 475 N. Linder Rd. Meridian ID. 83680 Contractor
Nevada contractor's license number issued by the State Contractor's Board 0038018
Nevada driller's license number issued by the Division of Water Resources, the on-site driller M-2188
Signed Mike D. Cox
By driller performing actual drilling on site or contractor
Date 2-29-02

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627