WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT
Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 82112
Permit No.
Basin 102

NOTICE OF INTENT NO. 46728

1. OWNER Ron Sallor Nevada Wood Preserving
MAILING ADDRESS Pacific Wood Preserving Companies 5601 District Blvd. Bakersfield CA.
ADDRESS AT WELL LOCATION Nevada Wood Preserving 1680 Spruce Ave. Silver Springs Nv.

2. LOCATION NE ¼ SW ¼ Sec 30 T 16 N/S R 25 E Lyons County
PERMIT NO. NDEP # NV0022501 Issued by Water Resources | Parcel No. | Subdivision Name

3. WORK PERFORMED
☐ New Well ☐ Replace ☐ Recondition
☐ Deepen ☒ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☒ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Measured hole; at a depth of 50', water at a depth 41'; Set up Drill lower NWS Rod + hammer bottom out of well. Put tremie pipe to the bottom of 4" well + pump neat cement until it reaches the surface. Then cut PVC below grade.				

Date started 2-28-02 2002
Date completed 2-28-02 2002

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled ____ Feet Depth Cased ____ Feet

HOLE DIAMETER (BIT SIZE)

	From	To
Inches	Feet	Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)

Perforations:
Type perforation
Size perforation
From ____ feet to ____ feet
From ____ feet to ____ feet
From ____ feet to ____ feet
From ____ feet to ____ feet
From ____ feet to ____ feet

Surface Seal: ☐ Yes ☐ No
Depth of Seal 50'-0'
Placement Method: ☒ Pumped ☐ Poured
Seal Type: ☒ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☐ Yes ☐ No
From ____ feet to ____ feet

9. WATER LEVEL
Static water level 41' feet below land surface
Artesian flow ____ G.P.M. ____ P.S.I.
Water temperature <85° °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Haz-Tech Drilling Inc. (Contractor)
Address 475 N. Linder Rd. Meridian ID, 83680 (Contractor)
Nevada contractor's license number issued by the State Contractor's Board 0038018
Nevada driller's license number issued by the Division of Water Resources, the on-site driller M-2188
Signed ____ (By driller performing actual drilling on site or contractor)
Date 2-29-02

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627