WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 86131
Permit No.
Basin 092-A

NOTICE OF INTENT NO. 47720

1. OWNER EDDIE RHODES
MAILING ADDRESS 7507 Vista View Drive
Reno, Nevada 89506

ADDRESS AT WELL LOCATION 1210 Stampede
Reno, Nevada 89506

2. LOCATION SE ¼ SW ¼ Sec. 29 T 22N N/S R ~~18~~ 19 E Washoe County

PERMIT NO. (Issued by Water Resources) | 079-410-23 (Parcel No.) | Red Rock Estates #141 (Subdivision Name)

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☒ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Top soil		0	1	1
Brown clay with some boulders		1	4	3
Brown clay		4	12	8
Green sandy clay		12	86	74
Soft zone (NO WATER)		86	87	1
Greennsandy clay		87	146	59
Reddish brown sandy clays		146	189	43
Reddish brown volcanic rock		189	203	14
Fracture rock (app 3 GPM)	X	203	210	7
Black volcanic rock		210	214	4
Black fracture volcanic rock	X	214	224	10
Black volcanik rock		224	225	1

Date started May 3, 2002, 19
Date completed May 7, 2002, 19

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
20+		

8. WELL CONSTRUCTION
Depth Drilled 225 Feet Depth Cased 225 Feet

HOLE DIAMETER (BIT SIZE)

Inches	From (Feet)	To (Feet)
10	0	50
8 5/8	50	225

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8		.188	0	225

Perforations:
Type perforation factory sawed slot
Size perforation 3/32 x 3 x 5 around
From 182 feet to 222 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 50 feet
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☒ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 50 feet to 225 feet

9. WATER LEVEL
Static water level 143 feet below land surface
Artesian flow ~~20+~~ G.P.M. P.S.I.
Water temperature cold °F Quality clear

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name WAYNE DRILLING, INC. (Contractor)
Address P.O. BOX 12370 (Contractor)
RENO, NEVADA 89510
Nevada contractor's license number issued by the State Contractor's Board 0022549
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 923
Signed (By driller performing actual drilling on site or contractor)
Date May 9, 2002

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627