WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

# WELL DRILLER'S REPORT

**Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340**

OFFICE USE ONLY
Log No. 86132
Permit No. II N
Basin 092-B1

NOTICE OF INTENT NO. 47719

1. OWNER MARTIN & ELDA OBERHOLTZER
MAILING ADDRESS 230 East 5th Avenue
Sun Valleym Nevada 89433

ADDRESS AT WELL LOCATION Arrowhead Way
Reno, Nevada 89506

2. LOCATION SE ¼ NW ¼ Sec. 11 T. 20N N/S R. 19 E. Washoe County
PERMIT NO. (Issued by Water Resources) 552-050-11 (Parcel No.) Golden Valley (Subdivision Name)

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☒ Air ☐ Other

6. LITHOLOGIC LOG

| Material | Water Strata | From | To | Thickness |
|---|---|---|---|---|
| Top soil | | 0 | 2 | 2 |
| Brown sandy clay with decomposed granite | | 2 | 8 | 6 |
| Soft zone | | 8 | 10 | 2 |
| Brown sandy clay with decomposed granite | | 10 | 18 | 8 |
| Weathered granite, some clay streaks | | 18 | 37 | 19 |
| Weathered granite | | 37 | 46 | 9 |
| Gray granite | | 46 | 70 | 24 |
| Hard gray granite | | 70 | 165 | 95 |
| Fracture (NO WATER) | | 165 | 166 | 1 |
| Hard gray granite | | 166 | 190 | 24 |
| Fracture (NO WATER) | | 190 | 191 | 1 |
| Hard gray granite | | 191 | 264 | 73 |
| Weathered, fractured granite | X | 264 | 296 | 32 |
| Gray granite | | 296 | 300 | 4 |

Date started April 30, 2002, 19
Date completed May 2, 2002, 19

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

| G.P.M. | Draw Down (Feet Below Static) | Time (Hours) |
|---|---|---|
| 15.5 | | |

8. WELL CONSTRUCTION
Depth Drilled 300 Feet Depth Cased 300 Feet

HOLE DIAMETER (BIT SIZE)

| Inches | From Feet | To Feet |
|---|---|---|
| 10 | 0 | 50 |
| 8 5/8 | 50 | 300 |
| | | |

CASING SCHEDULE

| Size O.D. (Inches) | Weight/Ft. (Pounds) | Wall Thickness (Inches) | From (Feet) | To (Feet) |
|---|---|---|---|---|
| 6 5/8 | | .188 | 0 | 300 |
| | | | | |
| | | | | |

Perforations:
Type perforation factory sawed slot
Size perforation 3/32 x 3x 5 around
From 260 feet to 300 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 50 feet
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☒ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 50 feet to 300 feet

9. WATER LEVEL
Static water level 94 feet below land surface
Artesian flow ~~15.5~~ G.P.M. P.S.I.
Water temperature cold °F Quality clear

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name WAYNE DRILLING, INC. (Contractor)
Address P.O. BOX 12370 (Contractor)
RENO, NEVADA 89510

Nevada contractor's license number issued by the State Contractor's Board 0022549
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 923
Signed (By driller performing actual drilling on site or contractor)
Date May 6, 2002

(Rev. 3 91) USE ADDITIONAL SHEETS IF NECESSARY (01-027)