REPORT NO. A02.014

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

LOG NO. 86134
PERMIT NO.
BASIN 85

NOTICE OF INTENT NO. 47973

OWNER JANET JOHNSON/NAN WATZ
MAILING ADDRESS 7445 PATRINA, SPARKS, NV 89436

ADDRESS OF WELL 7445 PATRINA
SPARKS, NV 89436

2. WELL LOCATION NE 1/4 SW 1/4 SEC. 4 T 20N R 20 E WASHOE COUNTY

PERMIT NO LTR12/14/01 PARCEL NO 083-440-70 SUBDIVISION NAME

3. TYPE OF WORK
[ ] New Well [ ] Replace [ ] Recondition
[X] Deepen [ ] Plug [ ] Other

4. PROPOSED USE
[X] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [X] Rotary [ ] RVC
[ ] Air [X] Mud

6. LITHOLOGIC LOG

MATERIAL	STRATA	FROM	TO	THICKNESS
METAL IN BOTTOM		230	258	28
GREEN, BLACK & WHITE		258		
FRACTURED GRANITE	X	258	297	39

Notes : REFER TO ORIGINAL LOG FOR SEAL.

Date Started 02/11/02 Date Completed 02/13/02

7. WELL TEST DATA

TEST METHOD [ ] Bailer [ ] Pump [X] Air Develop

	GPM	DRAWDOWN	TIME (HRS)
	9+		3.5 HOURS

8. WELL CONSTRUCTION

Depth Drilled 297 Depth Cased 295

HOLE DIAMETER (BIT SIZE)

6 1/4 Inches 230 Feet 297 Feet
Inches Feet Feet
Inches Feet Feet

CASING SCHEDULE

Size OD	Weight/Ft	Wall Thickness	From	To
5"	9.66	.188	195	295

PERFORATIONS:
Type Perforation FACTORY Size Perforation 3/32 X 3
From 255 Feet to 275 Feet
From Feet to Feet
From Feet to Feet

SURFACE SEAL: [ ] Yes [ ] No
Seal Depth
PLACEMENT METHOD: [ ] Pumped [ ] Poured

SEAL TYPE:
[ ] Neat Cement
[ ] Cement Grout
[ ] Concrete Grout
[ ] Bentonite

GRAVEL PACKED: [ ] Yes [ ] No
From Feet to Feet

9. WATER LEVEL
Static Water Level 202 Feet Below Land Surface
Artesian Flow GPM PSI
Water Temperature COOL F Quality CLEAR

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name AQUA DRILLING & WELL SVC., INC.
Address 675 EDISON WAY
RENO, NV 89502

NV. CONTRACTOR'S LIC. NO 15291 DRILLER'S LIC. NO. ON SITE 1981

Signed [signature]
By driller performing actual drilling on site or contractor

Dated Feb. 18-02