WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 86135
Permit No.
Basin 102

NOTICE OF INTENT NO. 47450

1. OWNER Pete
MAILING ADDRESS
ADDRESS AT WELL LOCATION

2. LOCATION SE ¼ NE ¼ Sec. 9 T. 18 N/S R. 25 E. Lyon County
PERMIT NO. (Issued by Water Resources) 15-241-08 (Parcel No.) (Subdivision Name)

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☑ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☑ Rotary ☐ RVC
☑ Air ☑ Other Mud

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Soil Boulders		0	3	
Boulders Cemented		3	57	
Tan clay		57	212	
Brown Sand stone Hard		212	218	
Tan Sand stone		215	235	
Gray Brown Hard Volcanic		235	273	
Brown Clay with Rock		273	302	
Gray Volcanic with Cracks		302	335	
Volcanic Fractured Broken Lost mud		335	346	
Fractured Broken		346	351	
Gray clay with Rocks		351	360	

Date started 12-21 2001
Date completed 12-23 2001

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☑ Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
40	GPM		

8. WELL CONSTRUCTION
Depth Drilled 360 Feet Depth Cased 360 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
12 1/4 Inches	0 Feet	260 Feet
9 7/8 Inches	260 Feet	360 Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
8 5/8	16.00	3/16	+1	360

Perforations:
Type perforation Mill Slot
Size perforation 1/4 x 2 Cols Single Row
From 300 feet to 360 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☑ Yes ☐ No
Depth of Seal 0-50
Placement Method: ☐ Pumped ☑ Poured
Seal Type: ☐ Neat Cement ☑ Cement Grout ☐ Concrete Grout

Gravel Packed: ☑ Yes ☐ No
From 50 feet to 360 feet

9. WATER LEVEL
Static water level 220 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name [signature] Contractor
Address PO Box 599 Silver Springs NV 89429 Contractor
Nevada contractor's license number issued by the State Contractor's Board 0031841
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2877
Signed [signature] By driller performing actual drilling on site or contractor
Date 12-23-02

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627