WHITE - DIVISION OF WATER RESOURCES
CANARY - CLIENT'S COPY
PINK - WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 86141
Permit No.
Basin 87

NOTICE OF INTENT NO. 47838

1. OWNER Dick Fiscus
MAILING ADDRESS 245 Finch Way
Carson, NV 89704

ADDRESS AT WELL LOCATION 168 Peponita Court
Washoe Valley

2. LOCATION NW 1/4 SE 1/4 Sec. 5 T 16N N/S R 20E E Washoe County
PERMIT NO. Issued by Water Resources
050 301 76 Parcel No.
Subdivision Name

3. WORK PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other

4. PROPOSED USE
[X] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [X] Rotary [ ] RVC
[X] Air [X] Other Mud

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
DG		0	8	8
Brown Sandy Clay		8	11	3
Sand & Coarse Gravel		11	38	27
Sand & DG		38	75	37
Clay		75	78	3
DG		78	82	4
Brown Granite		82	140	58
Black & White Granite		140	162	22
Brown Granite	X	162	320	158
Black & White Granite	X	320	335	15

Water well permit Washoe Co. # WL 020 008

Date started 01/22/2002 , 19__
Date completed 02/02/2002 , 19__

7. WELL TEST DATA
TEST METHOD: [ ] Bailer [X] Pump [X] Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
Air Lift	50		2 HR
Pump Test	27	12	2 HR

8. WELL CONSTRUCTION
Depth Drilled 335 Feet Depth Cased 335 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
10 5/8	Inches	0	Feet	200	Feet
6 1/8	Inches	200	Feet	335	Feet
	inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	12.92	.188	+2	200
5	10.79	.188	185	335

Perforations:
Type perforation Machine Cut
Size perforation 3/32 X 2

From	80	feet to	100	feet
From	180	feet to	200	feet
From	195	feet to	215	feet
From	295	feet to	335	feet
From		feet to		feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 50
Placement Method: [ ] Pumped [X] Poured

Seal Type:
[ ] Neat Cement
[X] Cement Grout
[ ] Concrete Grout

Gravel Packed: [X] Yes [ ] No
From 50 feet to 200 feet

9. WATER LEVEL
Static water level 63 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature Cool °F Quality Not tested

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Bruce MacKay Pump & Well Service, Inc. Contractor
Address 1600 Mt. Rose Hwy Contractor
Reno, NV 89511
Nevada contractor's license number issued by the State Contractor's Board 23096
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1719
Signed R. Bruce MacKay
By driller performing actual drilling on-site or contractor
Date 02/08/2002

USE ADDITIONAL SHEETS IF NECESSARY