WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 86142
Permit No.
Basin Ø92-B

NOTICE OF INTENT NO. 50403

1. OWNER TROY HICKS
MAILING ADDRESS 5250 Villa Verde Dr. #K1
Reno, Nevada 89523

ADDRESS AT WELL LOCATION 9435 Hungry Mountain Drive
Reno, Nevada 89506

2. LOCATION NE ¼ NW ¼ Sec. 11 T. 21N N/S R. 19 E. Washoe County
PERMIT NO. (Issued by Water Resources) 089-020-05 (Parcel No.) Lemmon Valley (Subdivision Name)

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☒ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Decomposed granite		0	35	35
Gray granite		35	61	26
Decomposed granite		61	63	2
Gray meduim hard granite		63	126	63
Soft zone (rusty clay)		126	127	1
Gray medium hard granite		127	173	46
Rusty brown granite		173	181	8
Gray granite		181	261	80
Soft zone, some clay streaks		261	265	4
Gray granite		265	441	176
Soft zone (No water)		441	444	3
Gray medium hard granite		444	592	148
Fracture (app 2 GPM)	X	592	596	4
Gray dark granite		596	618	22
FRacture granite	X	618	655	37
Gray granite		655	700	45

Date started April 18, 2002, 19
Date completed April 25, 2002, 19

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
17.5		

8. WELL CONSTRUCTION
Depth Drilled 700 Feet Depth Cased 700 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
10 Inches		0 Feet	50 Feet
8 5/8 Inches		50 Feet	700 Feet
Inches		Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8		.188	0	700

Perforations:
Type perforation factory sawed slot
Size perforation 3/32 x 3 x 5 around
From 615 feet to 655 feet
From 674 feet to 694 feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 50 foot
Placement Method: ☒ Pumped ☐ Poured
Seal Type: ☒ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 50 feet to 700 feet

9. WATER LEVEL
Static water level 490 feet below land surface
Artesian flow G.P.M. 17.5 P.S.I.
Water temperature cold °F Quality clear

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name WAYNE DRILLING, INC. (Contractor)
Address P.O.BOX 12370 (Contractor)
RENO, NEVADA 89510
Nevada contractor's license number issued by the State Contractor's Board 0022549
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 923
Signed (By driller performing actual drilling on site or contractor)
Date April 27, 2002

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627