WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 86144
Permit No.
Basin 104

NOTICE OF INTENT NO. 46113

1. OWNER Silver oaks C.C. (Mr. Garth Richards)
MAILING ADDRESS 1251 country club dr.
Carson City, NV 89703

ADDRESS AT WELL LOCATION
Evergreen & Chardonay dr. Carson City
Next to 4th green on Golf Course

2. LOCATION NW ¼ NW ¼ Sec. 6 T 15 N/S R 20 E Douglas County
PERMIT NO. Nev 94015 (Issued by Water Resources) Parcel No. Silver oaks Development (Subdivision Name)

3. WORK PERFORMED
☑ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☑ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☐ Air ☑ Other Scenic

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Fill dirt for Sod & Golf Course		Ø	2.5	2.5
Alluvium - dark brown little Sand		2.5	23	20.5
lighter brown increasing Sands		23	60'	37'
material mixed sand	63'	60'	195'	135'
and little gravel with				
stringers of Decomposed				
granite (3'-5' thick); wet no				
flowing sands; little silt				
Increasing silts with		195'	250'	
less sands and more clays				
(water strata all the way				
down hole; no aqua hard)				
	250'			

Date started 4/29/02, 19
Date completed 5/3/02, 19

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 250' Feet Depth Cased 250' Feet

HOLE DIAMETER (BIT SIZE)

		From	To
6" Inches	Ø Feet	250' Feet	
8" Inches	Ø Feet	250' Feet	
Inches	Feet	Feet	

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
4"	sch 80	sch 80	Ø	50'

Perforations:
Type perforation Factory
Size perforation 020
From 50' feet to 250' feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☑ Yes ☐ No
Depth of Seal 42'
Placement Method: ☑ Pumped ☐ Poured
Seal Type: ☑ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☑ Yes ☐ No
From 45' feet to 251' 250' feet

9. WATER LEVEL
Static water level 57' feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Brent Longyear (Contractor)
Address 32 stokes Dr Dayton NV 89403 (Contractor)
Nevada contractor's license number issued by the State Contractor's Board 0021976
Nevada driller's license number issued by the Division of Water Resources, the on-site driller M-2168
Signed (By driller performing actual drilling on site or contractor)
Date 5/4/02

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627