WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 86145
Permit No.
Basin 104

NOTICE OF INTENT NO. 46112

1. OWNER Silver oaks C.C. (Morbeath Richard)
MAILING ADDRESS 1351 country club dr.
Carson city, NV 89403

ADDRESS AT WELL LOCATION
Evergreen & Chardonney dr Carson city
250 yard's down 6th fairway

2. LOCATION NW ¼ NW ¼ Sec. 6 T. 15 N/S R. 20 E. County
PERMIT NO. Nev 94015 (Issued by Water Resources) Parcel No. Silver oaks Development (Subdivision Name)

3. WORK PERFORMED
☑ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☑ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☐ Air ☑ Other Sonic

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Fill dirt for Sod on Golf Course		0	1.5	1.5
Alluvium mixed 10% sand				
5% Gravel 85% silt/clay		1.5	50'	
50% Sand 25% silt 25%	52.5	50'	52.5	
Gravel ¼" to 1" wet				
Mixed Material Sand		52.5	180	
and little gravel with				
silt & strayers of decomposed				
Granite (3' to 5' Rock) wet				
no flowing sands; little silt				
55% silt 35% sand 10% gravel		180'	253'	
Increasing silt on way		180'	253	
down drilling harder				
decreasing sand with more				
clay layers				
(water strata all the way				
down no aqua hard)				
	253'			

Date started 4/22/02, 19
Date completed 4/29/02, 19

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 253 Feet Depth Cased 253 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
6" Inches	0 Feet	253 Feet	
8" Inches	0 Feet	253 Feet	
Inches	Feet	Feet	

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
4"	sch 80	sch 80	0	53'

Perforations:
Type perforation Factory
Size perforation 020
From 53' feet to 253' feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☑ Yes ☐ No
Depth of Seal 45'
Placement Method: ☑ Pumped ☐ Poured
Seal Type: ☑ Neat Cement ☐ Cement Grout ☐ Concrete Grout
Gravel Packed: ☑ Yes ☐ No
From 48' feet to 253 feet

9. WATER LEVEL
Static water level 52.5' feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Board Longyear (Contractor)
Address 32 Stokes Dr Dayton NV (Contractor)
89403
Nevada contractor's license number issued by the State Contractor's Board 0021976
Nevada driller's license number issued by the Division of Water Resources, the on-site driller M-2168
Signed (By driller performing actual drilling on site or contractor)
Date 5/1/02

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627