WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

# WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 86150
Permit No.
Basin Ø84

NOTICE OF INTENT NO. 38676

1. OWNER Reno-Spark S Indian Colony
MAILING ADDRESS 98 Colony Road
Reno, NV 89502

ADDRESS AT WELL LOCATION WW #2
Hungry Valley, Nevada

2. LOCATION SW ¼ SE ¼ Sec. 31 T. 22 N/S R. 20 E. Washoe County
PERMIT NO. W-540 (Issued by Water Resources) BLM (Parcel No.) Ø7C-Ø8Ø-53 (Subdivision Name)

3. WORK PERFORMED
☐ New Well ☐ Replace ☐ Recondition
☐ Deepen ☑ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☑ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☑ Rotary ☐ RVC
☐ Air ☐ Other mud

6. LITHOLOGIC LOG

| Material | Water Strata | From | To | Thickness |
|---|---|---|---|---|
| Circulate 60 visc. | | | | |
| Bentonite from | | | | |
| 550' to surface | | | | |
| Pull pipe back to | | | | |
| 50' and circulate | | | | |
| Neet cement to | | | | |
| surface. Pull pipe | | | | |
| and top off with | | | | |
| Neet cement | | | | |
| Plugging of log no. 86185 | | | | |

Date started 10-4-01, 19
Date completed 10-4-01, 19

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

| | G.P.M. | Draw Down (Feet Below Static) | Time (Hours) |
|---|---|---|---|
| | | | |

8. WELL CONSTRUCTION
Depth Drilled 550 Feet Depth Cased -0- Feet

HOLE DIAMETER (BIT SIZE)

| | From | To |
|---|---|---|
| 12 1/4 Inches | 0 Feet | 17 Feet |
| 9 7/8 Inches | 17 Feet | 550 Feet |
| Inches | Feet | Feet |

CASING SCHEDULE

| Size O.D. (Inches) | Weight/Ft. (Pounds) | Wall Thickness (Inches) | From (Feet) | To (Feet) |
|---|---|---|---|---|
| None | | | | |

Perforations:
Type perforation
Size perforation
From feet to feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☑ Yes ☐ No
Depth of Seal
Placement Method: ☑ Pumped ☐ Poured
Seal Type: ☑ Neat Cement ☐ Cement Grout ☐ Concrete Grout
Gravel Packed: ☐ Yes ☑ No
From feet to feet

9. WATER LEVEL
Static water level 119' feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Miller & Sons Drilling Co. (Contractor)
Address P.O. Box 8056 (Contractor)
Reno, NV 89507

Nevada contractor's license number issued by the State Contractor's Board 037915
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1418

Signed Bruce Miller
By driller performing actual drilling on site or contractor
Date 11-1-01

(Rev 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627